

UMGENI

Infrastructure Master Plan 2023 2023/2024 – 2053/2054 Volume 10: Wastewater



Infrastructure Development Division, Umgeni Water

310 Burger Street, Pietermaritzburg, 3201, Republic of South Africa
P.O. Box 9, Pietermaritzburg, 3200, Republic of South Africa
Tel: +27 (33) 341 1111 / Fax +27 (33) 341 1167 / Toll free: 0800 331 820
Email: info@umgeni.co.za / Web: www.umgeni.co.za





For further information, please contact:

Planning Services
Infrastructure Development Division
Umgeni Water

P.O.Box 9, Pietermaritzburg, 3200
KwaZulu-Natal, South Africa

Tel: 033 341-1522

Fax: 033 341-1218

Email: info@umgeni.co.za

Web: www.umgeni.co.za



UMGENI WATER

INFRASTRUCTURE MASTER PLAN 20232

2023/2024 – 2053/2054

JUNE 2023

Prepared by:

Graham Metcalf

Digitally signed by Graham Metcalf
DN: cn=Graham Metcalf, o=Umgeni Water,
ou=Planning Services,
email=graham.metcalf@umgeni.co.za, c=SC
Date: 2023.06.28 11:21:08 +02'00'

Graham Metcalf

Geohydrologist

Approved by:

**Kevin
Meier**

Digitally signed by Kevin Meier
DN: cn=Kevin Meier, o=Umgeni
Water, ou=Planning Services,
email=kevin.meier@umgeni.co.za,
c=ZA
Date: 2023.06.28 15:55:15 +02'00'

Kevin Meier PrEng

Manager: Planning Services

Kevin Meier

Digitally signed by Kevin Meier
DN: cn=Kevin Meier, o=Umgeni Water,
ou=Planning Services,
email=kevin.meier@umgeni.co.za, c=ZA
Date: 2023.06.30 12:35:48 +02'00'

DP

Xolani Chamane PrEng

Executive: Infrastructure Development

PREFACE

This Infrastructure Master Plan 2023 describes:

- Umgeni Water’s infrastructure plans for the financial period 2023/2024 – 2053/2054, and
- Infrastructure master plans for other areas outside of Umgeni Water’s Operating Area but within KwaZulu-Natal.

It is a comprehensive technical report that provides information on current infrastructure and on future infrastructure development plans. This report replaces the last comprehensive Infrastructure Master Plan that was compiled in 2022.

The report is divided into **ten** volumes as per the organogram below.

Volume 1 includes the following sections and a description of each is provided below:


- **Section 2** describes the most recent changes and trends within the primary environmental dictates that influence development plans within the province.
- **Section 3** relates only to the Umgeni Water Operational Areas and provides a review of historic water sales against past projections, as well as Umgeni Water’s most recent water demand projections, compiled at the end of 2021.
- **Section 4** describes Water Demand Management initiatives that are being undertaken by the utility and the status of Water Demand Management Issues in KwaZulu-Natal.
- **Section 5**, which also relates to Umgeni Water’s Operational Area, contains a high level review of the energy consumption used to produce the water volumes analysed in **Section 3**.
- **Section 6** provides an overview of the water resource regions and systems supplied within these regions.

The next eight volumes describe the current water resource situation and water supply infrastructure of the various systems in KwaZulu-Natal, including:

- **Volume 2 Section 7** Mgeni System.
- **Volume 3 Section 8** uMkhomazi System
- **Section 9** uMzimkhulu System
- **Section 10** Mzintlava System
- **Volume 4- Section 11** South Coast System
- **Volume 5 Section 12** North Coast System
- **Volume 6 Section 13** Upper uThukela System
- **Volume 7 Section 14** Buffalo System
- **Volume 8 Section 15** Middle uThukela System
- **Section 16** Mhlathuze System
- **Volume 9 Section 17** Umfolozi System
- **Section 18** uMkhuze / uPhongolo / Lake Sibiya System

Volume 10, Section 19 describes the wastewater works currently operated by Umgeni Water (shown in pale brown in the adjacent figure) and provides plans for development of additional wastewater treatment facilities. The status of wastewater treatment in WSA’s that are not supplied by Umgeni Water are also described in this section.

Infrastructure Master Plan 2023/2024



It is important to note that information presented in this report is in a summarised form and it is recommended that the reader refer to relevant planning reports if more detail is sought. Since the primary focus of this Infrastructure Master Plan is on bulk supply networks, the water resource infrastructure development plans are not discussed at length. The Department of Water and Sanitation (DWS), as the responsible authority, has undertaken the regional water resource development investigations. All of these investigations have been conducted in close collaboration with Umgeni Water and other major stakeholders in order to ensure that integrated planning occurs. Details on these projects can be obtained directly from DWS, Directorate: Options Analysis (East).

The Infrastructure Master Plan is a dynamic and evolving document. Outputs from current planning studies, and comments received on this document will therefore be taken into account in the preparation of the next update.

TABLE OF CONTENTS

| | |
|--|------|
| Preface | i |
| Table of Contents | iv |
| List of Figures | v |
| List of Tables | vii |
| List of Acronyms | viii |
| List of Units | xi |
| 19 Wastewater | 1 |
| 19.1 Overview..... | 1 |
| 19.2 Umgeni Water Owned Wastewater Works..... | 4 |
| 19.2.1Darvill Wastewater Works | 4 |
| 19.2.2Ixopo Wastewater Works..... | 11 |
| 19.2.3Albert Falls North and South Wastewater Works..... | 15 |
| 19.3 Umgeni Water Operated Wastewater Works..... | 18 |
| 19.3.1Howick Wastewater Works..... | 18 |
| 19.3.2Mpophomeni Wastewater Works..... | 23 |
| 19.3.3Lynnfield Park Wastewater Works..... | 26 |
| 19.3.4Mpofana Wastewater Works..... | 31 |
| 19.3.5Appelsbosch Wastewater Works | 36 |
| 19.3.6Cool Air Wastewater Works..... | 40 |
| 19.3.7Camperdown Wastewater Works..... | 44 |
| 19.3.8Richmond Wastewater Works | 48 |
| 19.3.9Trust Feeds Wastewater Works..... | 53 |
| 19.4 Recommended Projects | 56 |
| 19.4.1Darvill Wastewater Works Upgrade..... | 56 |
| 19.4.2Mpophomeni Wastewater Works Upgrade..... | 62 |
| 19.4.3Richmond Wastewater Works Upgrade | 65 |
| 19.4.4Mpofana Wastewater Works Upgrade | 68 |
| 19.4.5Mkhambathini Wastewater Works Upgrade | 70 |
| 19.4.6Hilton Bulk Wastewater Scheme..... | 74 |
| 19.5 New Areas | 77 |
| 19.5.1uThukela District Municipality | 77 |
| 19.5.2uMzinyathi District Municipality..... | 94 |
| 19.5.3iLembe District Municipality | 97 |
| 19.5.4Harry Gwala District Municipality | 101 |
| 19.5.5Ugu District Municipality..... | 105 |
| 19.5.6uMkhanyakude District Municipality | 109 |
| 19.5.7King Cetshwayo District Municipality..... | 113 |
| 19.5.8Zululand District Municipality | 117 |
| 19.5.9Amajuba District Municipality..... | 121 |
| Acknowledgements..... | l |

LIST OF FIGURES

| | | |
|--------------|---|----|
| Figure 19.1 | Location of Umgeni Water operated WWWs. | 2 |
| Figure 19.2 | Location of WWWs operated by Umgeni Water. | 3 |
| Figure 19.3 | Location of Darvill WWW. | 5 |
| Figure 19.4 | Average daily inflow (Mℓ/day) to Darvill WWW. | 6 |
| Figure 19.5 | Projected inflow into Darvill WWW. | 7 |
| Figure 19.6 | Analysis of historical production at Darvill WWW (November 2021 to October 2022). | 8 |
| Figure 19.7 | Darvill Aeration Basin. | 10 |
| Figure 19.8 | Location of Ixopo WWW. | 12 |
| Figure 19.9 | Clarifier No. 1 Ixopo WWW. | 13 |
| Figure 19.10 | Average daily inflow (Mℓ/day) for Ixopo WWW. | 13 |
| Figure 19.11 | Analysis of historical production at Ixopo WWW (November 2021 to October 2022). | 14 |
| Figure 19.12 | Sequencing Batch Reactor (SBR) Albert Falls North WWW. | 15 |
| Figure 19.13 | Location of Albert Falls North and South WWW. | 16 |
| Figure 19.14 | Howick WWW Chlorine Contact Tank. | 19 |
| Figure 19.15 | Location of Howick WWW. | 20 |
| Figure 19.16 | Howick WWW average daily outflows (Mℓ/day). | 22 |
| Figure 19.17 | Analysis of historical production at Howick WWW (November 2021 to October 2022). | 22 |
| Figure 19.18 | Location of decommissioned Mpophomeni WWW. | 25 |
| Figure 19.19 | Location of Lynnfield Park WWW. | 28 |
| Figure 19.20 | Lynnfield Park WWW average daily inflows (Mℓ/day). | 29 |
| Figure 19.21 | Lynnfield Park WWW head of works showing manual and mechanical screening channels. | 29 |
| Figure 19.22 | Analysis of historical production at Lynnfield Park WWW (November 2021 to October 2022). | 30 |
| Figure 19.23 | Mpofana WWW head of works. | 31 |
| Figure 19.24 | Location of the Mpofana WWW. | 32 |
| Figure 19.25 | Mpofana WWW average daily inflows (Mℓ/day). | 34 |
| Figure 19.26 | Analysis of historical production at Mpofana WWW (November 2021 to October 2022). | 35 |
| Figure 19.27 | Location of the Appelsbosch WWW. | 37 |
| Figure 19.28 | Appelsbosch WWW Oxidation Ditch (Aeration Tank). | 38 |
| Figure 19.29 | Appelsbosch WWW average daily outflows (Mℓ/day) | 39 |
| Figure 19.30 | Location of the Cool Air WWW. | 41 |
| Figure 19.31 | Different Mechanical Surface Aerators in Cool Air Reactor 1 and 2. | 42 |
| Figure 19.32 | Average daily inflows to Cool Air WWW (Mℓ/day). | 42 |
| Figure 19.33 | Analysis of historical production at Cool Air WWW (November 2021 to October 2022). | 43 |
| Figure 19.34 | Location of the Camperdown WWW. | 45 |
| Figure 19.35 | Average daily inflows to Camperdown WWW (Mℓ/day). | 47 |
| Figure 19.36 | Camperdown Clarifier No. 2. | 47 |
| Figure 19.37 | Location of the Richmond WWW. | 49 |
| Figure 19.38 | Richmond WWW clarifier. | 50 |
| Figure 19.39 | Average daily inflows to Richmond WWW (Mℓ/day). | 51 |
| Figure 19.40 | Analysis of historical production at Richmond WWW (November 2021 to October 2022). | 52 |

| | | |
|--------------|--|-----|
| Figure 19.41 | Location of Trust Feeds Wastewater Works. | 55 |
| Figure 19.42 | Upgrade of Darvill WWW. | 58 |
| Figure 19.43 | New head of works in the foreground with overflow channel teeing-off to the left. | 61 |
| Figure 19.44 | Upgrade of Mpophomeni WWW. | 63 |
| Figure 19.45 | Mpophomeni Wastewater Works New Head of Works | 64 |
| Figure 19.46 | Richmond WWW upgrade..... | 66 |
| Figure 19.47 | Mpofana WWW upgrade. | 69 |
| Figure 19.48 | Location of the proposed Mkhambathini WWW in relation to the existing Camperdown WWW. | 72 |
| Figure 19.49 | Proposed Mkhambathini WWW layout. | 73 |
| Figure 19.50 | Proposed Hilton WWW. | 76 |
| Figure 19.51 | Location of uThukela DM Wastewater Works | 78 |
| Figure 19.52 | Estcourt Wastewater Works Catchment Area | 80 |
| Figure 19.53 | Estcourt Wastewater Process Flow Diagram | 81 |
| Figure 19.54 | Wembezi Wastewater Works Catchment Area | 82 |
| Figure 19.55 | Wembezi Wastewater Works Process Flow Diagram | 83 |
| Figure 19.56 | Weenen Wastewater Works Catchment Area | 83 |
| Figure 19.57 | Weenen Wastewater Works Process Flow Diagram | 84 |
| Figure 19.58 | Ezakheni Wastewater Works Catchment Area | 85 |
| Figure 19.59 | Ezakheni Wastewater Works Process Flow Diagram | 85 |
| Figure 19.60 | Ekuvukeni Wastewater Works Catchment Area | 86 |
| Figure 19.61 | Ekuvukeni Wastewater Works Process Flow Diagram | 87 |
| Figure 19.62 | Ladysmith wastewater Works Catchment Area | 87 |
| Figure 19.63 | Ladysmith Wastewater Works Process Flow Diagram | 88 |
| Figure 19.64 | Colenso Wastewater Works Catchment Area | 89 |
| Figure 19.65 | Colenso Wastewater Works Process Flow Diagram..... | 90 |
| Figure 19.66 | Bergville Wastewater Works Catchment Area | 90 |
| Figure 19.67 | Bergville Wastewater Works Process Flow Diagram..... | 92 |
| Figure 19.68 | Winterton Wastewater Works Catchment Area | 93 |
| Figure 19.69 | Winterton Wastewater Works Process Flow Diagram..... | 94 |
| Figure 19.70 | Location of uMzinyathi Wastewater Works..... | 95 |
| Figure 19.71 | Location of iLembe District Municipality Wastewater Works | 98 |
| Figure 19.72 | Location of Harry Gwala District Municipality Wastewater Works | 102 |
| Figure 19.73 | Location of Ugu District Municipality Wastewater Works..... | 106 |
| Figure 19.74 | Location of uMkhanyakude District Municipality Wastewater Works | 110 |
| Figure 19.75 | City of uMhlathuze existing bulk sewerage sub-systems..... | 113 |
| Figure 19.76 | Location of King Cetshwayo King Cetshwayo District Municipality Wastewater Works . | 114 |
| Figure 19.77 | Location of Zululand District Municipality Wastewater Works | 118 |
| Figure 19.78 | Location of Amajuba District Municipality Wastewater Works | 122 |

LIST OF TABLES

| | | |
|-------------|--|-----|
| Table 19.1 | Darvill WWW infrastructure. | 4 |
| Table 19.2 | Ixopo WWW infrastructure. | 11 |
| Table 19.3 | Albert Falls North WWW infrastructure. | 17 |
| Table 19.4 | Albert Falls South WWW infrastructure. | 17 |
| Table 19.5 | Howick WWW infrastructure. | 21 |
| Table 19.6 | Mpophomeni WWW infrastructure. | 24 |
| Table 19.7 | Lynnfield WWW infrastructure. | 27 |
| Table 19.8 | Mpofana WWW infrastructure. | 33 |
| Table 19.9 | Appelsbosch WWW infrastructure. | 38 |
| Table 19.10 | Cool Air WWW infrastructure. | 40 |
| Table 19.11 | Camperdown WWW infrastructure. | 46 |
| Table 19.12 | Richmond WWW infrastructure. | 50 |
| Table 19.13 | Trust Feeds WWW infrastructure. | 54 |
| Table 19.14 | Project information: Darvill Wastewater Works Upgrade. | 59 |
| Table 19.15 | Project information: Mpophomeni Wastewater Works Upgrade. | 62 |
| Table 19.16 | Project information: Richmond Wastewater Works. | 65 |
| Table 19.17 | uThukela District Municipality Wastewater Works Specifications (DWS, 2011)..... | 79 |
| Table 19.18 | MIG funded Sanitation Projects in uThukela District Municipality (CoGTA KwaZulu-Natal,2020) | 79 |
| Table 19.19 | uMzinyathi District Municipality Wastewater Works Specifications (DWS, 2011) | 96 |
| Table 19.20 | MIG funded Sanitation Projects in uMzinyathi District Municipality (CoGTA KwaZulu-Natal)..... | 96 |
| Table 19.21 | iLembe District Municipality Wastewater Works Specifications (DWS, 2011)..... | 99 |
| Table 19.22 | MIG funded Sanitation Projects in iLembe District Municipality (CoGTA KwaZulu-Natal, 2020) | 100 |
| Table 19.23 | Harry Gwala District Municipality Wastewater Works Specifications (DWS, 2011)..... | 103 |
| Table 19.24 | MIG funded Sanitation Projects in Harry Gwala District Municipality (CoGTA KwaZulu-Natal, 2020) | 104 |
| Table 19.25 | Ugu District Municipality Wastewater Works Specifications | 107 |
| Table 19.26 | MIG funded Sanitation Projects in Ugu District Municipality (CoGTA KwaZulu-Natal, 2020)..... | 108 |
| Table 19.27 | uMkhanyakude District Municipality Wastewater Works Specifications (DWS, 2011) | 111 |
| Table 19.28 | MIG funded Sanitation Projects in uMkhanyakude District Municipality (CoGTA KwaZulu-Natal, 2020) | 112 |
| Table 19.29 | King Cetshwayo District Municipality Wastewater Works Specifications (DWS, 2011) | 115 |
| Table 19.30 | MIG funded Sanitation Projects in King Cetshwayo District Municipality (CoGTA KwaZulu-Natal, 2020) | 116 |
| Table 19.31 | Zululand District Municipality Wastewater Works Specifications (DWS, 2011)..... | 119 |
| Table 19.32 | MIG funded Sanitation Projects in Zululand District Municipality (CoGTA KwaZulu-Natal, 2020) | 120 |
| Table 19.34 | Amajuba District Municipality Wastewater Works Specifications (DWS, 2011) | 123 |
| Table 19.35 | MIG funded Sanitation Projects in Amajuba District Municipality (CoGTA KwaZulu-Natal, 2020)..... | 123 |

LIST OF ACRONYMS

| | |
|---------------|---|
| AADD | Annual Average Daily Demand |
| AC | Asbestos Cement |
| ADWF | Average Dry Weather Flow |
| API | Antecedent Precipitation Index |
| AVGF | Autonomous Valveless Gravity Filter |
| BID | Background Information Document |
| BPT | Break Pressure Tank |
| BWL | Bottom Water Level |
| BWSP | Bulk Water Services Provider |
| BWSS | Bulk Water Supply Scheme |
| CAPEX | Capital Expenditure |
| CMA | Catchment Management Agency |
| CoGTA | Department of Co-operative Governance and Traditional Affairs |
| CWSS | Community Water Supply and Sanitation project |
| DAEA | Department of Agriculture and Environmental Affairs |
| DEA | Department of Environmental Affairs |
| DEFF | Department of Environment, Forestry and Fisheries |
| DM | District Municipality |
| DRDLR | Department of Rural Development and Land Reform |
| DWA | Department of Water Affairs |
| DWS | Department of Water and Sanitation |
| DWAF | Department of Water Affairs and Forestry |
| EFR | Estuarine Flow Requirements |
| EIA | Environmental Impact Assessment |
| EKZN Wildlife | Ezemvelo KZN Wildlife |
| EMP | Environmental Management Plan |
| EWS | eThekweni Water Services |
| EXCO | Executive Committee |
| FC | Fibre Cement |
| FL | Floor level |
| FSL | Full Supply level |
| GCM | General Circulation Model |
| GDP | Gross Domestic Product |
| GDPR | Gross Domestic Product of Region |
| GVA | Gross Value Added |
| HDI | Human Development Index |
| IDP | Integrated Development Plan |
| IFR | In-stream Flow Requirements |
| IMP | Infrastructure Master Plan |
| IRP | Integrated Resource Plan |

| | |
|--------|--|
| ISP | Internal Strategic Perspective |
| IWRM | Integrated Water Resources Management |
| KZN | KwaZulu-Natal |
| LM | Local Municipality |
| LUMS | Land Use Management System |
| MA | Moving Average |
| MAP | Mean Annual Precipitation |
| MAR | Mean Annual Runoff |
| MBR | Membrane Bioreactor |
| MMTS | Mooi-Mgeni Transfer Scheme |
| MMTS-1 | Mooi-Mgeni Transfer Scheme Phase 1 |
| MMTS-2 | Mooi-Mgeni Transfer Scheme Phase 2 |
| mPVC | Modified Polyvinyl Chloride |
| MTEF | Medium-Term Expenditure Framework |
| MTSF | Medium-Term Strategic Framework |
| MWP | Mkomazi Water Project |
| MWP-1 | Mkomazi Water Project Phase 1 |
| NCP-1 | North Coast Pipeline I |
| NCP-2 | North Coast Pipeline II |
| NCSS | North Coast Supply System |
| NGS | Natal Group Sandstone |
| NPV | Net Present Value |
| NRW | Non-Revenue Water |
| NSDP | National Spatial Development Perspective |
| NWSP | National Water Sector Plan |
| OPEX | Operating Expenditure |
| p.a. | Per annum |
| PES | Present Ecological Status |
| PEST | Political, Economical, Sociological and Technological |
| PGDS | Provincial Growth and Development Strategy |
| PPDC | Provincial Planning and Development Commission (KZN's) |
| PSEDS | Provincial Spatial Economic Development Strategy |
| PWSP | Provincial Water Sector Plan |
| RDP | Reconstruction and Development Programme |
| RO | Reverse Osmosis |
| ROD | Record of Decision |
| RQO | Resource Quality Objective |
| SCA | South Coast Augmentation |
| SCP | South Coast Pipeline |
| SCP-1 | South Coast Pipeline Phase 1 |
| SCP-2a | South Coast Pipeline Phase 2a |
| SCP-2b | South Coast Pipeline Phase 2b |

| | |
|---------|--|
| SDF | Spatial Development Framework |
| SHR | St Helen’s Rock (near Port Shepstone) |
| STEEPLE | Social/demographic, Technological, Economic, Environmental (Natural), Political, Legal and Ethical |
| SWRO | Seawater Reverse Osmosis |
| TEC | Target Ecological Category |
| TWL | Top Water Level |
| uPVC | Unplasticised Polyvinyl Chloride |
| UW | Umgeni Water |
| WA | Western Aqueduct |
| WC | Water Conservation |
| WDM | Water Demand Management |
| WMA | Water Management Area |
| WRC | Water Research Commission |
| WSA | Water Services Authority |
| WSDP | Water Services Development Plan |
| WSNIS | Water Services National Information System |
| WSP | Water Services Provider |
| WTP | Water Treatment Plant |
| WWW | Wastewater Works |

Spellings of toponyms have been obtained from the Department of Arts and Culture (DAC). DAC provides the official spelling of place names and the spellings, together with the relevant gazette numbers, can be accessed at <http://www.dac.gov.za/content/toponymic-guidelines-map-and-other-editors>.

When using any part of this report as a reference, please cite as follows:

Umgeni Water, 2023. *Umgeni Water Infrastructure Master Plan 2023/2024 – 2053/54, Vol 1 - 10*. Prepared by Planning Services, June 2023.

LIST OF UNITS

| | | |
|---|-------------------------------|--------------------------------|
| Length/Distance: | mm | millimetre |
| | m | metre |
| | km | kilometre |
| Area: | m ² | square metres |
| | ha | hectare |
| | km ² | square kilometres |
| Level/Altitude: | mASL | metres above sea-level |
| Time: | s | second |
| | min | minute |
| | hr | hour |
| Volume: | m ³ | cubic metres |
| | Mℓ | megalitre |
| | million m ³ | million cubic metres |
| | mcm | million cubic metres |
| Water Use/Consumption/Treatment/Yield: | ℓ/c/day | litre per capita per day |
| | kℓ/day | kilolitre per day |
| | Mℓ/day | megalitre per day |
| | million m ³ /annum | million cubic metres per annum |
| | kg/hr | kilograms per hour |
| Flow velocity/speed: | m/s | metres per second |
| Flow: | m ³ /s | cubic metres per second |
| | ℓ/hr | litres per hour |
| | m ³ /hr | cubic metres per hour |

19 WASTEWATER

19.1 Overview

Umgeni Water operates a number of Wastewater Works (WWW). These are shown in relation to the existing water system configurations as shown in **Figure 19.1** and discussed in **Section 6 in Volume 1** and are illustrated in the preface above. Umgeni Water owns and operates the Darvill, Ixopo, Albert Falls North and South WWW, but manages and operates a number of other WWW on behalf of municipalities (**Figure 19.2**). Management contracts are in place for the operation and maintenance of the Howick, Cool Air, Mpofana, Appelsbosch, Camperdown, Trust Feeds and Richmond WWW for the uMgungundlovu District Municipality (UMDM) and the Lynnfield Park WWW for the Msunduzi Local Municipality. The new Mpophomeni WWW in the UMDM, is currently being constructed and will be operated by Umgeni Water once complete. All the WWW operations use aeration basins for biological nutrient removal and clarifiers for the separation process.





Figure 19.1 Location of Umgeni Water operated WWWs.




Figure 19.2 Location of WWTWs operated by Umgeni Water.

19.2 Umgeni Water Owned Wastewater Works

19.2.1 Darvill Wastewater Works

a) Description

The Darvill WWW is the largest and most significant under Umgeni Water's management and serves the Msunduzi Local Municipality. A summary of the characteristics of the Darvill WWW are shown in **Table 19.1** and the location of Darvill WWW in Msunduzi Municipality is shown in **Figure 19.3**.

Table 19.1 Darvill WWW infrastructure.

| | |
|--|--|
| WWW Name: | Darvill WWW |
| System: | Upper Mgeni System |
| Maximum Design Capacity: | 120 Mℓ/day |
| Current Utilisation: | 77 Mℓ/day |
| Screens: | 2 x Front raked bar screen followed by 3 mm stepped screen; 1 x Hand raked by-pass 25 mm screen |
| Balancing Tank: | 10 Mℓ/day |
| Primary Settling Tanks: | 4 (3 x 20 Mℓ/day; 2 x 40 Mℓ/day) |
| Settled Sewage Pump Station: | 150 Mℓ/day |
| Aeration Basin Area: | |
| Aeration Basin Capacity: | 74 415 m ³ |
| Aerators: | Diffused aeration |
| Clarifier Type: | Circular scraped floor |
| Number of Clarifiers: | 7 |
| Total Area of all Clarifiers: | 6720 m ² |
| Total Capacity of Clarifiers: | 120 Mℓ/day |
| Upflow Velocity: | 1 m/h |
| RAS Pump Station Capacity: | 120 Mℓ/day |
| Primary Sludge Thickeners | 2 |
| Anaerobic Digesters: | 4 (4 x 4500 m ³) |
| Chlorine Storage Capacity: | 18 x 900 kg drums |
| Chlorine Dosing Capacity: | 7.5 mg/ℓ |
| Total Capacity of Chlorine Contact Tanks: | |
| Total Capacity of Sludge Treatment Plant: | |
| Wash Water Capacity: | 2 Mℓ/day |
| Sludge Irrigation Area: | |




Figure 19.3 Location of Darvill WWTW .

b) Status Quo

In 2011 a decision was made to upgrade the WWW to 100 Mℓ/day as the plant had been operating above its capacity. The average daily inflow (November 2021 to October 2022) is 77 Mℓ/day (Figure 19.4) which is above the plant's previous treatment capacity.

Inflows to the works have been fairly static over the last five years and have not increased with demand increases as would be expected (Figure 19.4). There appears to have been a gradual increase in inflows over the last year, however, this may have been influenced by the high rainfall and flooding that occurred in April 2022. Higher than normal return flows (7.1% above the previous year) resulted from excess storm water runoff. The 12 month moving average in Oct 2017 was 66 Mℓ/day and in Oct 2022 it was 77 Mℓ/day. This does reflect a positive increase in inflows. The average daily inflow for past five years is, however, still low at 73 Mℓ/day. Umgeni Water therefore remains concerned that not all of the wastewater return flows are reaching the WWW due to spillages and leaking sewers (see Figure 7.16 in Volume 2), which is resulting in losses. Losses within the Msunduzi sewer catchment are undoubtedly a contributing factor in why the anticipated increase in wastewater demand is not being realised.




Figure 19.4 Average daily inflow (Mℓ/day) to Darvill WWWW.

The plant capacity was increased by 35 Mℓ/day in 2018 to cope with the predicted wastewater demands (Figure 19.5). ADWF within the Darvill WWWW catchment was expected to grow to about 90 Mℓ/day by 2021 (Figure 19.5), although this is not reflected on the graph due to the sharp drop in influent in 2017. This drop was due to various construction and maintenance activities impacting on the flow. The upgraded design allows for future expansion to a maximum capacity of 120 Mℓ/day,

which is forecast to occur in 2028. Some of the proposed demand scenarios are illustrated in **Figure 19.5**.




Figure 19.5 Projected inflow into Darvill WWT.

An analysis of daily historical production (November 2021 to October 2022) for the upgraded Darvill WWT is presented in **Figure 19.6**. It shows that for 43% of the time the WWT was being operated above the optimal operating capacity. The plant operated above the new 100 Ml/day design capacity for 14% of the time.




Figure 19.6 Analysis of historical production at Darvill WWW (November 2021 to October 2022).

c) Recommendations

The upgraded WWW plant comprises the following unit processes:

- Storm water overflow and storage facility
- Excess storm water chlorination facility and storm water return pump installation
- Inlet works with Fat, Oils, Grease and Grit (FOGG) removal facility
- Primary sedimentation tanks
- Activated sludge process (anaerobic, anoxic, and aeration zones (**Figure 19.7**))
- Aluminum sulfate addition to assist phosphate removal
- Secondary clarifiers for separation and return of activated sludge
- Chlorination of final effluent
- Pre-thickener for primary sludge
- Anaerobic Digesters
- Sludge dewatering facility (linear screens) and disposal
- Wash Water Plant

The inlet works consists of two inlet channels each equipped with hand raked coarse screens, four mechanical screens (installed in pairs), four vortex flow grit separators complete with submersible centrifugal grit pumps, grit classifier and belt conveyor with screenings compactor and flow measurement. The Fat, Oils and Grease (FOG) plant is combined with grit removal as an element of the inlet works to form a Fat, Oils, Grease and Grit removal facility (FOGG).

Primary treatment consists of four primary settling tanks (PST), two 30 m in diameter and two 40 m in diameter. Primary sewage is fed from the PSTs to a balancing tank (10 Mℓ).

Primary settled sewage is transferred and lifted from the balancing tank by the main pump station to an elevated level at the activated sludge tanks inlet from where the sewage receives secondary treatment. The pump station consists of two receiving sumps with two large horizontal split casing centrifugal pumps servicing each sump. A central manifold connects the two pump sets to allow for interchangeable operation. The two pumps, per sump, operate in a full duty/standby configuration and are designed to operate in a flow range of 70 – 130 Mℓ/day.

The activated sludge plant at Darvill WWWW consists of a number of pre anoxic / anoxic / anaerobic zones followed by the aeration basin. A total biological volume of 74 415 m³ is provided in the new system. Aeration in the aerobic zone of the biological reactor is achieved with fine bubble diffused air (FBDA) aeration. Air is supplied to the system by four duty and one standby blower.

Secondary treatment consists of seven clarifiers with a Return Activated Sludge (RAS) pump station fitted with centrifugal pumps operating on variable speed drives. The effluent from the clarifiers is disinfected using a high concentration chlorine solution which is discharged into the effluent upstream of the chlorine contact tank.

The chlorine disinfection unit process is followed by a series of maturation rivers / lagoons. In total there are three rivers / lagoons with a combined volume of 20 428 m³ giving a total retention time of 8.2 hours for the design flow of 60 Mℓ/day.

The sludge treatment system has two sources of sludge produced and subsequently processed. Primary sludge withdrawn from the underflow of the primary sedimentation tanks is forwarded to a gravity sludge thickening stage before passing through a pre-fermentation process and then onto anaerobic digestion. The pre-fermentation process produces a supernatant high in volatile fatty acids (VFA's) which is returned to the liquid treatment phase and aids in denitrification ahead of the aeration basis.

The methane gas generated by the anaerobic digestion process will, in future, be utilised in a co-generation plant to produce electricity. The co-generation gas engines will be cooled by water and this water will be utilised in the digesters for heating purposes. The digested sludge will pass into the post thickeners and then be dewatered and treated with lime to provide a stable product which may be used for agricultural purposes or landfill cover.

The second sludge phase is the wasting of activated sludge. At Darvill WWWW mixed liquor is wasted directly from the activated sludge reactor upstream of the final clarifiers. The waste mixed liquor will gravitate to a new building housing linear screens where it will be thickened to 6%. The sludge to the linear screens will be dosed with a cationic polyacrylamide conditioning polyelectrolyte. Thereafter it will be blended with the digested sludge and disposed of on the sludge lands adjacent to the WWWW site.

The high pressure water system will operate at a pressure of 8 bar with two duty and one standby pumps. The high pressure water system will draw treated water directly from the wash water treatment plant.



Figure 19.7 Darvill Aeration Basin.

19.2.2 Ixopo Wastewater Works

a) Description

Ixopo WWW serves the town of Ixopo in the Harry Gwala District Municipality and is a Class D accredited WWWW. It is located next to the R612 regional road and downstream of the Home Farm Dam, which supplies the raw water to Umgeni Water's Ixopo WTP (**Figure 19.8**).

The Ixopo WWWW process train follows a typical extended aeration process consisting of an inlet works, one reactor with three aerators on timers and two clarifiers (**Figure 19.9**), five drying beds and chlorine contact channels. Sludge is dried on beds and disposed of on a local farm owned by Harry Gwala District Municipality. The characteristics of the Ixopo WWWW are shown in **Table 19.2**.

Table 19.2 Ixopo WWWW infrastructure.

| | |
|--|---|
| WWW Name: | Ixopo WWWW |
| System: | uMkhomazi System |
| Maximum Design Capacity: | 1 Mℓ/day |
| Current Utilisation: | 0.29 Mℓ/day |
| Balancing Ponds: | 3 Mℓ |
| Raw Sewage Pump Station: | |
| Screens: | 1 x Hand raked, 2.5 cm gaps |
| Grit Chambers: | 2 x Constant velocity grit channel |
| Aeration Basin Area: | |
| Aeration Basin Capacity: | 1150 m ³ |
| Aerators: | 3 x 18.5 kW slow speed aerators |
| Clarifier Type: | 1 x scraped floor (12.5 m), 1 x suction lift (14.5 m) |
| Number of Clarifiers: | 2 |
| Total Area of all Clarifiers: | 274 m ² |
| Total Capacity of Clarifiers: | 6.6 Mℓ/day |
| Upflow Velocity: | 1 m/h |
| RAS Pump Station Capacity: | |
| Chlorine Storage Capacity: | 8 x 68 kg cylinders |
| Chlorine Dosing Capacity: | 0 – 1 kg/h |
| Total Capacity of Chlorine Contact Tanks: | 62 m ² |
| Total Capacity of Sludge Treatment Plant: | |
| Anaerobic Ponds: | None |
| Sludge Drying Beds Area: | 720 m ² |




Figure 19.8 Location of Ixopo WWW.



Figure 19.9 Clarifier No. 1 Ixopo WWW.

b) Status Quo

The average daily inflow to the Ixopo WWW is shown in **Figure 19.10**.




Figure 19.10 Average daily inflow (Mℓ/day) for Ixopo WWW.

Flows to the WWW have, for a number of years, been reduced as a result of blockages in the Ixopo sewer network and non-operational pump stations. The situation improved somewhat over the last year as evidenced in **Figure 19.10**. The anticipated return flows are approximately 1.3 Mℓ/day, so the improvement is still substantially less than required in order for the sewer system to be operating effectively.

Of concern is that sewage meant for the works is undoubtedly spilling into the environment and polluting water resources as well as placing communities at risk. Sampling from Umgeni Water’s Home Farm Dam indicates elevated ammonia and phosphorous levels as a direct result of pollution from sewage (**Section 7.2.1(b)(iv)**). Operationally the low flows cause significant difficulties for process stability and this impacts negatively on achieving compliance with discharge standards.

An analysis of daily historical production (November 2021 to October 2022) for the Ixopo WWWW is presented in **Figure 19.11**. It shows that for 1.1 % of the time the WWWW was being operated above the optimal operating capacity. The plant operated above the design capacity 0.8 % of the time. This shows the plant is being vastly underutilised, especially considering that it was upgraded in October 2016 with the installation of a second clarifier.




Figure 19.11 Analysis of historical production at Ixopo WWWW (November 2021 to October 2022).

c) Recommendations

The underutilisation of the plant makes the operation of the plant uneconomical and results in many operational problems. For example, without a consistent inflow the aeration of the biological reactor is difficult to maintain at the correct level. The biomass is also difficult to sustain as there is a limited food source resulting in process issues.

19.2.3 Albert Falls North and South Wastewater Works

a) Description

Albert Falls North (**Figure 19.12**; **Figure 19.13**) and South WWW (**Figure 19.13**) are aerobic sequencing batch reactors (SBRs) with design capacities of 55 m³/day and 40 m³/day respectively. Raw sewage from the staff quarters, surrounding households and tankers is fed into the reactor via two grit channels at the Northern works and through a sump at the Southern works. Equalisation, biological treatment and secondary clarification are performed in a single tank using a timed control sequence.

The system is fitted with diffusers for oxygen supplied by two blowers for biological nutrient removal. Solid-liquid separation occurs in the reactor during an idle period when no diffusion or mixing takes place, allowing the solids to settle and a sludge-blanket to form. The diffusion occurs when the actuator valve is in a closed position and decanting occurs after the diffusion process is completed. Supernatant flows through a chlorination unit including a contact tank for disinfection. The chlorinated effluent then gravitates to a maturation pond for further stabilization and polishing. After the maturation pond the final effluent is discharged to the environment.

The available clarifiers are no longer in use for clarification but serve as a safe guard for over spill during actuator valve failure and pipe blockages. Waste Activated Sludge (WAS) is discharged to the neighbouring sludge drying beds. The characteristics of the Albert Falls North and South WWW are shown in **Table 19.3** and **Table 19.4** respectively.



Figure 19.12 Sequencing Batch Reactor (SBR) Albert Falls North WWW.



Figure 19.13 Location of Albert Falls North and South WWW.

Table 19.3 Albert Falls North WWW infrastructure.

| | |
|--|------------------------------|
| WWW Name: | Albert Falls North WWW |
| System: | Upper Mgeni System |
| Maximum Design Capacity: | 0.055 Mℓ/day |
| Current Utilisation: | Unknown (No inflow meter) |
| Screens: | None |
| Grit Chambers: | 2 x grit channels |
| Aeration Basin: | 1 x Sequencing Batch Reactor |
| Aeration Basin Capacity: | 165 m ³ |
| Aeration: | 8 x Fine Bubble Diffuses |
| Blowers: | 2 x 7.5 kW |
| Clarifier Type: | Used as overflow tank |
| Number of Clarifiers: | 2 |
| Total Area of all Clarifiers | NA |
| Total Capacity of Clarifiers: | 20 m ³ |
| Chlorine Storage Capacity: | Calcium Hypochlorite tablets |
| Total Capacity of Chlorine Contact Tanks: | 11.34 m ³ |
| Sludge Drying Beds Area: | 51 m ² |
| Maturation Pond Capacity: | 475 m ³ |

Table 19.4 Albert Falls South WWW infrastructure.

| | |
|--|------------------------------|
| WWW Name: | Albert Falls WWW |
| System: | Upper Mgeni System |
| Maximum Design Capacity: | 0.055 Mℓ/day |
| Current Utilisation: | Unknown (No inflow meter) |
| Screens: | None |
| Grit Chambers: | 2 x grit channels |
| Aeration Basin: | 1 x Sequencing Batch Reactor |
| Aeration Basin Capacity: | 115 m ³ |
| Aeration: | 6 x Fine Bubble Diffuses |
| Blowers: | 2 x 7.5 kW |
| Clarifier Type: | Used as overflow tank |
| Number of Clarifiers: | 2 |
| Total Area of all Clarifiers: | NA |
| Total Capacity of Clarifiers: | 20 m ³ |
| Chlorine Storage Capacity: | Calcium Hypochlorite tablets |
| Total Capacity of Chlorine Contact Tanks: | 11.34 m ³ |
| Sludge Drying Beds Area: | 46 m ² |
| Maturation Pond Capacity: | 140 m ³ |

b) Status Quo

The current Albert Falls North and South sanitation systems are very small without any significant bulk reticulation to be considered. Existing stands in this area are primarily serviced by waterborne sewage in the north and by septic tanks in the south.

c) Recommendations

The main infrastructure elements to be upgraded/added include:

- New mains are proposed within the range of 250 mm \varnothing - 200 mm \varnothing in pipe size to service the conversion of a neighbouring peri-urban area Thokozani. In addition to these future mains, the flow will need to be diverted from Albert Falls North to a new proposed WWWW. The conversion of the southern septic tanks (approximately 163 stands) to waterborne sanitation will also result in the flow from Albert Falls South being diverted in future, however no additional future mains other than those specified above will be required for the septic tank conversion.
- It is estimated that the ultimate flow contribution from the Msinsi Bon Accorde Resort, the development in the surrounding Albert Falls North area and the conversion of Thokozani which is currently serviced by VIPs will be approximately 977 k ℓ /day which significantly exceeds the current capacity of Albert Falls North and Albert Falls South works. Therefore, it is proposed that a new WWWW, with design capacity 1000 k ℓ /day, be implemented to accommodate future flows. The existing Albert Falls North and South plants should be decommissioned with existing flows being diverted to the new proposed plant.

This project will be triggered when development of the future development areas (FDAs) listed above occurs. Both conversion of the peri-urban area Thokozani and conversion of existing septic tank areas have been given a 30-year priority in the phasing approach employed.

19.3 Umgeni Water Operated Wastewater Works

Umgeni Water is responsible for the operation and maintenance of six wastewater works (Mpophomeni WWWW is currently decommissioned) within the UMDM¹. Additionally, Umgeni Water operates the Lynnfield Park WWWW on behalf of the Msunduzi Local Municipality.

19.3.1 Howick Wastewater Works

a) Description

Howick WWWW (**Figure 19.15**) is situated in the town of Howick in the Natal Midlands. It is owned by UMDM and operated by Umgeni Water. The WWWW is a Class C accredited WWWW with an extended aeration process consisting of three separate reactors and four clarifiers. All reactors follow the Johannesburg Process configuration and are fitted with mechanical mixers in the anoxic and anaerobic zones and with surface aerators in the aerobic zones. Mixed liquor from the basins is settled in four downstream clarifiers. Waste activated sludge from the reactors is dewatered in drying beds and treated effluent is disinfected using chlorine (**Figure 19.14**) before being discharged to the uMngeni

¹ In 2014 Umgeni Water entered into a management contract to manage all the wastewater works within UMDM, having previously only operated the Howick WWWW.

River. Howick WWT is operating within its overall design capacity for the biological removal of COD, ammonia and phosphate.



Figure 19.14 **Howick WWT Chlorine Contact Tank.**

The characteristics of the Howick WWT are summarised in **Table 19.5**.




Figure 19.15 Location of Howick WWT.

Table 19.5 Howick WWW infrastructure.

| | |
|--|--|
| WWW Name: | Howick WWW |
| System: | Upper Mgeni System |
| Maximum Design Capacity: | 6.8 Mℓ/day |
| Current Utilisation: | 4.61/day |
| Raw Sewage Pump Station: | |
| Screens: | 2 x Hand Raked, 5.5 cm 1 x Mechanical Screen Raker, 1 cm (Huber); 0.75 kW Motor (Bauer) |
| Screw Press: | Rotary Screw Conveyor; 0.55 kW Motor (Flender) |
| Grit Chambers: | 2 x Vortex Degritters |
| Degritter Pump: | 2 x Airlift; 7.5 kW (Wade) |
| Anaerobic Basin Mixers: | 6 x 1.5 kW, 3 x 2.2 kW Mixers |
| Anoxic Basin Mixers: | 9 x 2.2 kW Mixers |
| Aerators: | 3 x 15.5 kW (Hansen) 3 x 18.5 kW (WEG), 4 x 30 kW (Hansen) |
| Anaerobic Basin Area: | 575 m ² |
| Anoxic Basin Area: | 640 m ² |
| Aeration Basin Area: | 1790 m ² |
| Aeration Basin Capacity: | 1.7 Mℓ/day , 1.7 Mℓ/day and 3.4 Mℓ/day (9850 m ³) |
| Clarifier Type: | 2 x Suction Lift, 2 x Mechanically Scraped |
| Number of Clarifiers: | 4 |
| Total Area of all Clarifiers: | 830 m ² |
| Total Capacity of Clarifiers: | 20 Mℓ/day |
| Upflow Velocity: | 1 m/h |
| RAS Pump Station: | |
| Chlorine Storage Capacity: | 68 kg Cylinder |
| Chlorine Dosing Capacity: | |
| Total Capacity of Chlorine Contact Tanks: | 9 Mℓ/day |
| Total Capacity of Sludge Treatment Plant: | |
| Sludge Dewatering: | 2 x Mechanical Screw Presses (Max. 5 m ³ /h) |
| Sludge Drying Beds Area: | 1920 m ² |

Howick WWW (**Table 19.5**) has a design capacity of 6.8 Mℓ/day and is currently treating 4.61 Mℓ/day (**Figure 19.16**) based on a 12-month moving average. This includes (2 – 3 Mℓ/day) wastewater pumped from the decommissioned Mpophomeni WWW (**Section 19.3.2**). Mechanical dewatering equipment installed in 2013 has alleviated operational problems to a degree although the works still has capacity constraints within some processes.

b) Status Quo

An analysis of daily historical production (November 2021 to October 2022) of the Howick WWW is presented in **Figure 19.17**. It shows that for 37 % (68% in 2021) of the time the WWW was being

operated above the optimal operating capacity. The plant operated above design capacity 12% (31% in 2021) of the time.




Figure 19.16 Howick WWW average daily outflows (M£/day).




Figure 19.17 Analysis of historical production at Howick WWW (November 2021 to October 2022).

There has been a significant drop in the over-utilisation of the plant. In comparison to the previous period the plant operated 31 % less above optimum operating capacity. This was largely down to the implementation of ESKOM load-shedding, which resulted in Bridge Road (and other) sewage pump stations not operating for large periods. Subsequently the flows into the works were reduced. Umgeni Water has installed a stand-by generator system at Bridge Road to alleviate this problem in future.

c) Recommendations

The upgrading of major existing bulk infrastructure between the intersection of Main Road/Harvard Street and the Howick WWW, including the works, will be required because of upstream development. Septic tank conversions will also play a role in the required sizing.

The main infrastructure elements to be upgraded include:

- i) The outfall between the intersection of Main Road/Harvard Street and Bridge Road Pump Station;
- ii) Bridge Road Pump Station and 770mm rising main to the works;
- iii) Upgrading of Howick WWW and inlet works.

These upgrades should be triggered when relative spare capacity remaining in the bulk infrastructure elements nears 30%.

The ultimate capacity of Howick WWW will be 17 Mℓ/day if those areas currently served by septic tanks are converted to water borne sewage. This ultimate capacity accounts for all future developments in and around Howick as well as projected growth in demand. The availability of additional land is an issue since the current site is not well utilized in terms of treatment capacity per hectare. There are two options available one being elaborated on hereunder. The second option is to decommission the existing drying beds to avail space for additional units or different technology that will accommodate the proposed additional capacity.

In discussions with the DM, it was confirmed that the land parcel immediately north of the works is municipal land. This land must be secured as soon as possible and reserved for the expansion of the WWW.

The Howick WWW is situated on Erf 997 due south from the CBD. This Erf has a size of approximately 72837 m² (7.28 ha). The figure above shows various land users/ coverages at and around the Howick WWW site. The fenced off area has an extent of 3.77 ha, encompassing all the current treatment processes. There is fenced and unfenced land that form part of Erf 997. Also, some portion of Erf 997 (Northeast) has been taken up by an informal settlement (in the extent of 17614 m² or 1.76 ha. The area not taken up by informal settlements is therefore 5.52 ha. The land north of Howick WWW in the approximate extent of 2.41 Hectares and would be an ideal option to expand the plant to.

19.3.2 Mpophomeni Wastewater Works

a) Description

Presently wastewater from Mpophomeni Township is pumped from the site of the decommissioned Mpophomeni WWW (**Figure 19.18**) to Howick WWW (**Section 19.3.1**), a distance of approximately 11 km. The existing wastewater pumping and conveyance system, with an estimated operating capacity of 4.3 Mℓ/day, is inadequate to pump the projected ADWF of 5.9 Mℓ/day. Umgeni Water

started construction of a new WWW in Mpophomeni in mid-2020 (**Section 19.4.2**). The new WWW has been designed to treat 6 Mℓ/day with the possibility of increasing the capacity to 12 Mℓ/day. The site has adequate land available for a WWW of at least 20 Mℓ/day. The existing WWW infrastructure is listed in **Table 19.6**, some of which will be retained as part of the new plant.

Table 19.6 Mpophomeni WWW infrastructure.

| | |
|--|---|
| WWW Name: | Mpophomeni WWW |
| System: | Upper Mgeni System |
| Maximum Design Capacity: | 3.5 Mℓ/day |
| Current Utilisation: | Decommissioned |
| Balancing Ponds: | 2.25 Mℓ/day wet weather storage pond |
| Raw Sewage Pump Station: | |
| Screens: | 1 x 30 mm Manually raked 1 x Mechanical Screen Raker (Huber) |
| Grit Chambers: | 2 x Vortex |
| Primary Settling Tank: | 2 |
| Rotating Biofilters: | 2 x 454 m ² |
| Clarifier Type: | |
| Number of Clarifiers: | 1 x 18 m diameter |
| Total Area of all Clarifiers | 255 m ² |
| Total Capacity of Clarifiers: | 6 Mℓ/day |
| Upflow Velocity: | 1 m/h |
| Cold Digesters: | 2 x 600 kℓ |
| Supernatant Tank: | 1 x 450 kℓ |
| Humus Tanks: | 3 |
| RAS Pump Station: | |
| Chlorine Storage Capacity: | |
| Chlorine Dosing Capacity: | |
| Total Capacity of Chlorine Contact Tanks: | |
| Total Capacity of Sludge Treatment Plant: | |
| Dewatering Facility: | |
| Sludge Drying Beds Area: | 8 |




Figure 19.18 Location of decommissioned Mpopomeni WWWW.

b) Status Quo

As indicated in **Section 19.3.2 a)**, wastewater from Mpophomeni Township is pumped from the site of the decommissioned Mpophomeni WWW (**Figure 19.18**) to Howick WWW. Therefore refer to **Section 19.3.1b)** for the status quo.

c) Recommendations

Brookdales development just north of Howick Airfield and shooting range is likely to be constructed before (estimated 2026) any other future developments in the Mpophomeni wastewater catchment. The internal sewer infrastructure, sewer outfall and pump station (PS), which is situated approximately 500 m north of the development, have already been designed.

A new bulk main from the Brookdales pump station (PS) to the Mpophomeni WWW is required. This will comprise a 3 km rising main from the PS, to the natural watershed located approximately 1.2 km north-east of the works along the R617. From this point a new future main will gravitate all sewage to the WWW.

As the Brookdales PS is located at the lowest point, other proposed developments adjacent to the R617 will be able to naturally drain towards the PS.

19.3.3 Lynnfield Park Wastewater Works

a) Description

The Lynnfield Park WWW is a small (0.5 Mℓ/day) works that services part of the Ashburton area (**Figure 19.19**). Umgeni Water took over the operation of the works on behalf of the Msunduzi Local Municipality in April 2014. Inflow to the works averaged 0.29 Mℓ/day on a twelve month moving average (**Figure 19.20**), up from 0.21 Mℓ/day the previous year. Despite the increase this is well below the works capacity. Prior to the installation of a flow measuring device no records were available and hence inflow readings only started in May 2017. The WWW was upgraded in 2016 with the addition of a new Sequencing Batch Reactor (SBR). The old extended aeration activated sludge reactors were decommissioned and are now used as balancing tanks and chlorine contact tanks. The Head of Works (HOW) was upgraded and comprises two channels comprising manual and mechanical screening (**Figure 19.21**).

The addition of a duplicate SBR (0.5 Mℓ/day) is planned and this would increase the capacity of the plant to 1 Mℓ/day. Any upgrades to the works are being funded by a private developer and thus the increase in capacity is being timed to coincide with planned property developments in the area. Further upgrades to 2 and 4 Mℓ/day are planned based on expected future requirements.

The characteristics of the Lynnfield Park WWW are shown in **Table 19.7**.

Table 19.7 Lynnfield WWW infrastructure.

| | |
|--|---|
| WWW Name: | Lynnfield WWW |
| System: | Upper Mgeni System |
| Maximum Design Capacity: | 0.5 Mℓ/day |
| Current Utilisation: | 0.29 Mℓ/day |
| Balancing Ponds: | Storm Dam |
| Screens: | New 1 x Mechanical raked screen, 6 mm aperture New standby 1 x Hand raked screen, 12 mm aperture |
| Grit Chambers: | 1 x vortex |
| Aeration Basin: | 2 x Sequencing Batch Reactor |
| Aeration Basin Capacity: | 500 kℓ/day |
| Aeration: | Fine Bubble Diffused Aeration |
| Blowers: | 2 x 9.5 kW |
| Clarifier Type: | |
| Number of Clarifiers: | 2 (decommissioned) |
| Total Area of all Clarifiers: | |
| Total Capacity of Clarifiers: | |
| Upflow Velocity: | |
| Chlorine Storage Capacity: | 25 ℓ tank Liquid Sodium Hypochlorite (NaOCL) |
| Total Capacity of Chlorine Contact Tanks: | 11.34 m ³ |
| Sludge Drying Beds Area: | Geofabric dewatering bag contained in a disposable skip |




Figure 19.19 Location of Lynnfield Park WWTW.




Figure 19.20 Lynnfield Park WWW average daily inflows (M/d/day).



Figure 19.21 Lynnfield Park WWW head of works showing manual and mechanical screening channels.

b) Status Quo

A sharp decline in flow in 2019, as a result of blockages in the sewer network, is visible in **Figure 19.20**. These blockages appear to have been cleared by the Msunduzi Municipality as the flow returned to historical volumes in 2020. The inflow has shown a gradual increase over the last two years, which cannot readily be attributed to any particular reason. Improved network management may be a contributing factor, although large rainfall events such as the April 2022 floods have also increased inflow.

An analysis of daily historical production (November 2021 to October 2022) of the Lynnfield Park WWW is presented (**Figure 19.22**). It shows that for 8.7 % of the time the WWW was being operated above the optimal operating capacity. The plant operated above design capacity 3.0% of the time.




Figure 19.22 Analysis of historical production at Lynnfield Park WWW (November 2021 to October 2022).

c) Recommendations

The WWW is operating well within its capacity and there is therefore no need for an upgrade in the near future.

19.3.4 Mpofana Wastewater Works

a) Description

Umgeni Water operates the Mpofana WWW (**Figure 19.23**) on behalf of UMDM. The wastewater works services the town of Mooi River, and adjacent township of Bruntville (**Figure 19.24**). Sewage from Mooi River flows into the works by gravity whilst catchment sewage is pumped to the wastewater works by eight pump stations.



Figure 19.23 Mpofana WWW head of works.




Figure 19.24 Location of the Mpofana WWW.

The characteristics of the Mpofana WWW are shown in **Table 19.8**.

Table 19.8 Mpofana WWW infrastructure.

| | |
|--|---|
| WWW Name: | Mpofana WWW |
| System: | Mooi System |
| Maximum Design Capacity: | 3.5 Mℓ/day |
| Current Utilisation: | 1.5 Mℓ/day |
| Balancing Ponds: | Combined 75000 m ³ |
| Raw Sewage Pump Station: | 375 Mℓ/day @ velocity of 2.3 m/s |
| Screens: | 3 x Hand-raked bar screen |
| Grit Chambers: | None |
| Aeration Basin: | 2 x Activated sludge (1 x not operational) |
| Aeration Basin Capacity: | Operational 4500 m ³ |
| Aerators: | 3 x Hansen QVPD-3_UDN (45kW, 1480 rpm) 3 x SEW Eurodrive (not operational) |
| Clarifier Type: | Suction Lift Clarifier |
| Number of Clarifiers: | 2 x 20 m diameter |
| Total Area of all Clarifiers: | 628 m ² |
| Total Capacity of Clarifiers: | 15 Mℓ/day |
| Upflow Velocity: | 1 m/h |
| RAS Pump Station: | None (gravity) |
| Chlorine Storage Capacity: | Wallace & Tiernan, S10k Gas Chlorinator 68 kg cylinder |
| Chlorine Dosing Capacity: | Max. allowable 2.0 kg/h (existing) |
| Total Capacity of Chlorine Contact Tanks: | 25m ³ |
| Total Capacity of Sludge Treatment Plant: | 5 m ³ /hr |
| Dewatering Facility: | Operational |
| Sludge Drying Beds Area: | None |

b) Status Quo

The works has a design capacity of 3.5 Mℓ/day and is currently treating 1.5 Mℓ/day based on a twelve-month moving average (**Figure 19.25**). The works did receive approximately 1.2 Mℓ/day of industrial influent from the adjacent textile industry until it suffered a major fire in October 2019. The factory currently remains closed.




Figure 19.25 Mpofana WWW average daily inflows (Mℓ/day).

Due to zero inflow from the textile factory the average inflow of 1.5 Mℓ/day no longer exceeds the capacity of the works (**Figure 19.25**). A contributing factor to the low flows entering the works are ongoing sewage network problems. Many of the sewage pump stations are not operational for long periods of time resulting in considerable environmental pollution. An analysis of daily historical production (November 2021 to October 2022) of the Mpofana WWW is presented in **Figure 19.26**. It shows that for 4% (21% in 2021) of the time the WWWW is being operated above the optimal operating capacity. The plant operated above design capacity 1% (6% in 2020) of the time. As can be seen from the graph the plant is now operating within its optimum operating capacity for the majority of the time. The plant is thus not hydraulically stressed as in the past. Low flows are the cause of this as sewage pump stations are often not operating due to breakdowns. The situation is exacerbated by load shedding.

The Detailed Feasibility Study (DFS) for the upgrade of the works has been suspended following a review of the project (**Section 19.4.5**). However, a number of operational issues have been identified at the works (mainly due to aging infrastructure) and these will be scheduled for refurbishment or replacement under a new project. The refurbishment project will increase the capacity of the works to meet demands and improve the treatment process sufficiently to meet effluent discharge standards.




Figure 19.26 Analysis of historical production at Mpofana WWT (November 2021 to October 2022).

c) Recommendations

A number of future development areas (FDAs) have been identified in Mooi River through various sources. Proposed projects include those that would address backlogs as well as new developments. The resultant increase in demand requires that the main outfall that leads to the WWT be upgraded. The upgrade, therefore caters to all developments in the Mooi River town and Bruntville township area.

The Mpofana WWT outfalls with an existing nominal diameter of 300 mm \varnothing were simulated under the theoretical zoning and future development demands associated with this development scenario. The results showed that the bulk outfalls will require upgrades within the range of 525 mm \varnothing - 400 mm \varnothing in pipe size.

Additionally, analysis showed that the section of the outfall directly after the rising main, is a flatter slope than the pipes upstream and downstream, and due to this flat slope, the hydraulic model indicates that the pipe be upgraded to 400 mm \varnothing .

There are three main areas in the Mpofana scheme boundary that are serviced by septic and conservancy tanks, namely Penningdale, Brickyards and Mooi River Industrial conservancy tanks. Penningdale is located adjacent the Mpofana WWT, where the western side of converted septic tanks could drain directly into the main outfall for the Mpofana WWT. Furthermore, with the main outfall for the Mpofana WWT already catering for the larger flows from Mooi River town and Bruntville Township, the additional flow from these three areas will not be significant enough to trigger a larger upgrade to the outfall other than what is already specified.

These projects will be triggered when development of FDAs, listed above, occurs. Both conversion of the peri-urban areas and conversion of existing septic tank areas have been given a 30-year priority in the phasing approach employed.

19.3.5 Appelsbosch Wastewater Works

a) Description

The Appelsbosch WWW is situated in Appelsbosch in the uMshwathi Municipality (**Figure 19.27**). The WWW comprises a single rectangular aeration tank fitted with turbine aerators (**Figure 19.28**), a clarifier, three anaerobic ponds and a chlorine contact tank. The current treatment capacity is reported as 0.5 Mℓ/day. The plant receives sewerage from the Hospital, College and Appelsbosch Waterworks, although the Waterworks was decommissioned in November 2019. The plant is classified as a Class D works requiring a Class 1 operator onsite and a Class V supervisor available who does not necessarily have to be onsite. The characteristics of the Appelsbosch WWW are shown in **Table 19.9**.

b) Status Quo

The Appelsbosch WWW flows are represented in the graph (**Figure 19.29**) and it is apparent that the flows are very small with a 12 month moving average of 0.07 Mℓ/day in October 2022.



Figure 19.27 Location of the Appelsbosch WWTW.



Figure 19.28 Appelsbosch WWT Oxidation Ditch (Aeration Tank).

Table 19.9 Appelsbosch WWT infrastructure.

| | |
|--|---------------------|
| WWW Name: | Appelsbosch WWT |
| System: | Upper Mgeni System |
| Maximum Design Capacity: | 0.5 Mℓ/day |
| Current Utilisation: | 0.07 Mℓ/day |
| Balancing Ponds: | None |
| Raw Sewage Pump Station: | Gravity |
| Screens: | 1 x Hand Raked |
| Grit Chambers: | None |
| Aeration Basin: | 1 x Oxidation Ditch |
| Aeration Basin Capacity: | 667 m ³ |
| Aerators: | 2 x Brush Aerators |
| Clarifier Type: | Scraped Floor |
| Number of Clarifiers: | 1 |
| Total Area of all Clarifiers | 38 m ² |
| Total Capacity of Clarifiers: | 0.9 Mℓ/day |
| Upflow Velocity: | 1 m/h |
| RAS Pump Station: | |
| Chlorine Storage Capacity: | |
| Chlorine Dosing Capacity: | |
| Total Capacity of Chlorine Contact Tanks: | |
| Total Capacity of Sludge Treatment Plant: | None |
| Anaerobic Ponds: | 3 (35 m x 10 m) |
| Sludge Drying Beds Area: | Not operational |




Figure 19.29 Appelsbosch WWW average daily outflows (Mℓ/day)

c) Recommendations

The flows are within the design capacity of the WWW and therefore there are no identified recommendations presently.

19.3.6 Cool Air Wastewater Works

a) Description

The Cool Air WWW is situated near the Cool Air Township (**Figure 19.30**) in the uMshwathi Local Municipality. The plant is owned by UMDM and operated by Umgeni Water. The plant is classified as a Class C and is required to have a Class 3 Operator, and a Class V Supervisor available. These staff do not necessarily have to be on the plant all of the time.

The WWW is an extended aeration activated sludge process (**Figure 19.31**) with two rectangular aeration tanks, two clarifiers and a chlorine contact tank. The characteristics of the Cool Air WWW are shown in **Table 19.10**.

Table 19.10 Cool Air WWW infrastructure.

| | |
|--|---------------------------------|
| WWW Name: | Cool Air WWW |
| System: | Upper Mgeni System |
| Maximum Design Capacity: | 1.5 Mℓ/day |
| Current Utilisation: | 0.55 Mℓ/day |
| Balancing Ponds: | None |
| Raw Sewage Pump Station: | Gravity |
| Screens: | Hand raked 1 x 3.5 cm, 1x2.0 cm |
| Grit Chambers: | None |
| Aeration Basin: | 2 x Extended aeration |
| Aeration Basin Capacity: | 2 x 883 m ³ |
| Aerators: | 2 x 4.48 kW, 2 x 7.5 kW |
| Clarifier Type: | 1 x suction lift, 1 x scraped |
| Number of Clarifiers: | 2 |
| Total Area of all Clarifiers: | 129 m ² |
| Total Capacity of Clarifiers: | 3.12 Mℓ/day |
| Upflow Velocity: | 1 m/h |
| RAS Pump Station: | 2 x Archimedes Screw Pumps |
| Chlorine Storage Capacity: | 68 kg cylinder chlorine gas |
| Chlorine Dosing Capacity: | 0 – 1 kg/h |
| Total Capacity of Chlorine Contact Tanks: | |
| Total Capacity of Sludge Treatment Plant: | None |
| Anaerobic Ponds: | None |
| Sludge Drying Beds Area: | 835 m ² |




Figure 19.30 Location of the Cool Air WWW.



Figure 19.31 Different Mechanical Surface Aerators in Cool Air Reactor 1 and 2.

b) Status Quo

Cool Air WWW has a design capacity of 1.5 Mℓ/day and is currently treating 0.55 Mℓ/day (Figure 19.32) based on a 12-month moving average. This is still well below the historical average and is possibly attributable to blockages in the sewer network. The issue has been raised as a concern with the uMgungundlovu District Municipality.




Figure 19.32 Average daily inflows to Cool Air WWWW (Mℓ/day).

An analysis of daily historical production (November 2021 to October 2022) of the Cool Air WWW is presented in **Figure 19.33**. It shows that for 6.5 % of the time the WWW was being operated above the optimal operating capacity. The plant operated above design capacity 3.8 % of the time.




Figure 19.33 Analysis of historical production at Cool Air WWW (November 2021 to October 2022).

c) Recommendations

The main Cool Air outfall leading to the Cool Air WWW steadily gravitates alongside the Mhlalane River from the North to the South through the centre of the Cool Air scheme boundary. The sewer network consists of 13 km of sewer reticulation. All gravity sewers in Cool Air have sufficient spare capacity when analysed according to the existing demand scenario and evaluation criteria. Additionally, as detailed above the metered inflows are far below the design capacity of the WWW.

The village of Dalton lies to the north of Cool Air and it is primarily serviced by septic tanks. In order to improve the level of service septic tank conversions to water borne sewage is proposed for the existing 109 stands. To accommodate the Dalton Septic tanks in the areas which naturally drain North-Easterly as opposed to draining towards the WWW in the South a pump station will be required. The proposed pump station will be accompanied by a proposed rising main leading to the Cool Air outfall. The proposed rising main will be approximately 930 m in length and 110 mm.

It is estimated that the ultimate flow contribution from the Cool Air town and the future developments areas (FDA) will be approximately 1750 kℓ/d. Therefore, the future capacity of Cool Air WWW should have a design capacity of 2000 kℓ/d to accommodate future flows. This project will be triggered when development of FDAs occurs, estimated around 2026 to 2041.

19.3.7 Camperdown Wastewater Works

a) Description

Camperdown WWW is situated in Camperdown (**Figure 19.34**) approximately half-way between Pietermaritzburg and Cato Ridge. The WWW falls within the Mkhambathini Local Municipality and UMDM, which is the WSA for the area. The plant is owned by UMDM and is operated by Umgeni Water. The plant is classified as a Class E works requiring a Class 1 Operator onsite and a Class V Supervisor available but not necessarily onsite.

The WWW has an extended aeration activated sludge process using a rectangular aeration tank and two scraped clarifiers. The characteristics of the Camperdown WWW are shown in **Table 19.11**.



Figure 19.34 Location of the Camperdown WWT.

Table 19.11 Camperdown WWW infrastructure.

| | |
|--|--|
| WWW Name: | Camperdown WWW |
| System: | Lower Mgeni System |
| Maximum Design Capacity: | 0.5 Mℓ/day |
| Current Utilisation: | 0.1 Mℓ/day |
| Balancing Ponds: | None |
| Raw Sewage Pump Station: | Gravity |
| Screens: | 1 x Hand Raked, 2.5 cm Gaps |
| Grit Chambers: | 1 x Vortex Degritter |
| Aeration Basin: | 1 |
| Aeration Basin Capacity: | 234 m ³ |
| Aerators: | 2 x 5.5 kW |
| Clarifier Type: | Scraped Floor |
| Number of Clarifiers: | 1 |
| Total Area of all Clarifiers: | 28 m ² |
| Total Capacity of Clarifiers: | 1 x 85 m ³ (New Steel) , 6.72 Mℓ/day, |
| Upflow Velocity: | 1 m/h |
| RAS Pump Station: | |
| Chlorine Storage Capacity: | Sodium Hypochlorite |
| Chlorine Dosing Capacity: | |
| Total Capacity of Chlorine Contact Tanks: | |
| Total Capacity of Sludge Treatment Plant: | |
| Anaerobic Ponds: | 1 x 30 m ² |
| Sludge Drying Beds Area: | 130 m ² |

b) Status Quo

Camperdown WWW (**Figure 19.36**) has a reported design capacity of 0.5 Mℓ/day and is currently treating 0.11 Mℓ/day (**Figure 19.35**) based on a 12-month moving average (0.01 Mℓ/day in 2021). There is a noticeable increase in inflow to the works over the last year. This can be partially attributed to the repair of sewage pump stations by the Municipality, but mainly due to improved flow meter accuracy.

An analysis of the daily historical production is not provided as the inflow data is not a true reflection of the volume of wastewater being produced in the catchment. Only a limited portion of sewage is actually reaching the plant rendering any analysis of plant capacity superfluous. It is, however, clear that the capacity of the works is more than sufficient for the foreseeable future as the average daily inflow is low in comparison to the works capacity. Currently the sewage network serves only a portion of Camperdown and this has been a constraint on development in the area (**Figure 19.34**). A detailed design has been completed for a new 2 Mℓ/day wastewater works named Mkhambathini WWW, to be located west of the N3 freeway (**Section 19.4.6**). This project requires that the UMDM first upgrade and expand the sewer reticulation network to accommodate all existing and future demand. Umgeni Water is engaging with UMDM in investigating alternative funding mechanisms for the project.




Figure 19.35 Average daily inflows to Camperdown WWW (Ml/day).



Figure 19.36 Camperdown Clarifier No. 2.

c) Recommendations

The existing Camperdown scheme will, in future, expand considerably to cater for vast expected future development along the N3 corridor. Additionally, the small existing Camperdown works is not located

in a suitable position to cater for this and as such should be decommissioned. A new interim Mkhambathini and ultimate Mkhambathini works at two different locations are proposed.

The interim Mkhambathini WWWW (**Section 19.4.5**) was proposed a decade ago and is based on 10 potential future development areas (FDAs) directly south of the existing scheme and N3 freeway. The proposed design capacity of the Mkhambathini WWWW is 2 Mℓ/day. However, an additional 12 potential FDA's have been identified in the Sanitation Master Plan study, some of which are downstream of the proposed WWWW location. A future wastewater works of much larger capacity (28 Mℓ/day) it thus proposed to meet the ultimate demand in the area.

The decommissioning of the existing Camperdown WWWW must include the construction of a PS (Camperdown PS 1), and a 650 m rising main to pump all sewage generated from the existing scheme to the watershed, located near the intersection of Alfred Storm Street and Horizon Place. Thereafter, a 3.1 km gravity main will be required to deliver sewage to the proposed low lift Camperdown PS 2. This PS and short rising main will pump sewage to the Mkhambathini (interim) WWWW. This infrastructure will also cater for the service level upgrade (septic tanks to waterborne) for approximately 130 existing stands immediately south of the existing scheme.

The majority of this project will be required regardless of whether the Municipality opt for the interim WWWW site or not, as most infrastructure will also be included in the ultimate operational configuration (excluding the works and low lift PS) and will therefore be triggered when any development occurs, expected around 2026.

19.3.8 Richmond Wastewater Works

a) Description

Umgeni Water operates the Richmond WWWW on behalf of UMDM. The wastewater works services the town of Richmond (**Figure 19.37**), but does not include the adjacent township of Ndaleni. Sewage from Richmond flows by gravity to the wastewater works.

The plant is an extended aeration activated sludge process consisting of an inlet works, a single rectangular aeration tank fitted with two surface aerators and a suction lift clarifier (**Figure 19.38**). Final treated wastewater is disinfected using chlorine gas.



Figure 19.37 Location of the Richmond WWWW.



Figure 19.38 Richmond WWW clarifier.

The works was designed for ADWF of 1 Mℓ/day with a COD loading of 740 kg/day. The WWW is classified as a Class E works requiring a Class 1 Operator onsite, and a Class V Supervisor available, but not necessarily onsite. The characteristics of the Richmond WWW are shown in **Table 19.12**.

Table 19.12 Richmond WWW infrastructure.

| | |
|--|---|
| WWW Name: | Richmond WWW |
| System: | Upper Mgeni System |
| Maximum Design Capacity: | 1 Mℓ/day (Based on ADWF) 2.9 Mℓ/day |
| Current Utilisation: | 0.77 Mℓ/day |
| Raw Sewage Pump Station: | T-series Gormann Rupp |
| Screens: | Hand-raked 11 mm gap bar screen |
| Grit Chambers: | Two |
| Aeration Basin: | Activated sludge |
| Aeration Basin Capacity: | 1110 m ³ |
| Aerators: | Two slow speed Hansen Patent (18.5 kW each) |
| Clarifier Type: | Suction Lift Clarifier |
| Number of Clarifiers: | 1 |
| Total Area of all Clarifiers: | 95 m ² |
| Total Capacity of Clarifiers: | 2.28 Mℓ/day |
| Upflow Velocity: | 1 m/h |
| RAS Pump Station: | T-series Gormann Rupp |
| Chlorine Storage Capacity: | 68kg cylinder |
| Chlorine Dosing Capacity: | Max. allowable 2.5 kg/h |
| Total Capacity of Chlorine Contact Tanks: | 25m ³ |
| Total Capacity of Sludge Treatment Plant: | Sludge lagoon (volume unknown) |
| Sludge Drying Beds Area: | 500 m ² (not used) |

b) Status Quo

Richmond WWW has a design capacity of 1.0 Mℓ/day and is currently treating 0.77 Mℓ/day based on a 12-month moving average (**Figure 19.39**). An upgrade of the works to 2 Mℓ/day (**Section 19.4.4**) was planned but this is currently on hold.




Figure 19.39 Average daily inflows to Richmond WWW (Mℓ/day).

An analysis of daily historical production (November 2021 to October 2022) of the Richmond WWW is presented in **Figure 19.40**. It shows that for 35 % of the time the WWWW was being operated above the optimal operating capacity. The plant operated above design capacity 20 % of the time. It would appear that the plant is operating above its optimum operating and design capacity beyond what is acceptable. Metering reading inaccuracies may, however, be distorting the picture, especially during storm events when they are prevalent.




Figure 19.40: Analysis of historical production at Richmond WWW (November 2021 to October 2022)

c) Recommendations

The existing Richmond scheme will expand to cater for future development areas located on the outskirts of town, and additionally, existing stands currently serviced by septic tanks may also be catered for within future waterborne schemes. These FDAs will require upgrades of the existing bulk infrastructure including the sewer outfalls and pump stations.

The following sections of existing sanitation network have insufficient capacity when analysed against the existing demand scenario and evaluation criteria and will need to be upgraded:

- The final 450 m section of 100 mm \varnothing sewer pipe gravitating along Nelson and Pine Streets into Richmond A PS to a 160 mm \varnothing .
- The final 100m section of 100mm \varnothing sewer pipe gravitating along Pine and Albert Streets into Richmond B PS to a 160 mm \varnothing .
- The 1.2km section of 200mm \varnothing outfall gravitating to the works to 350 mm \varnothing .

These projects will be triggered when development of FDAs listed above occurs. Both conversion of the peri-urban areas and conversion of existing septic tank areas have been given a 30-year priority in the phasing approach employed.

19.3.9 Trust Feeds Wastewater Works

a) Description

Construction of the Trust Feeds Wastewater Works and ancillary infrastructure is complete. Practical completion was achieved on 20 October 2020. The plant was handed over to Umgeni Water on 11 December 2020. The wet commissioning will, however, only be done once 500 low cost houses have been built and occupied.

The wastewater works will serve the existing Trust Feeds community as well as the new uMshwathi Ridge housing development (**Figure 19.41**). The ultimate capacity of the wastewater works will be 2 Mℓ/day, although initially only half the capacity has been constructed (1 Mℓ/day).

The WWW is located approximately 4 km north west of Wartburg, on the eastern periphery of the uMshwathi Local Municipality boundary within Ward 8 of uMshwathi Local Municipality.

The WWW will serve the following developments:

- The existing semi-formal low income housing development known as Trust Feeds, which comprises approximately 800 houses.
- The uMshwathi Ridge development is a 3000 unit low-income development, which has been approved by the Department of Human Settlements to eliminate the housing backlog within the region. The new development is adjacent to Trust Feeds and 500 units (Phase 1) will be constructed initially.

The plant is an extended aeration activated sludge process consisting of an inlet works including a mechanical screen, vortex grit chamber and flume type flow meter. The Biological Nutrient Removal (BNR) process consists of an activated sludge tank with return activated sludge (RAS) and waste activated sludge (WAS) pumping systems. Two circular 15 m diameter secondary clarifiers and chlorine disinfection complete the treatment process. The sludge is pumped to 15 rectangular drying beds.

The characteristics of the Trust Feeds WWW are shown in **Table 19.13**.

Table 19.13 Trust Feeds WWW infrastructure.

| | |
|--|---|
| WWW Name: | Trust Feeds WWW |
| System: | Upper Mgeni System |
| Maximum Design Capacity: | 1 Mℓ/day (Based on ADWF) |
| Current Utilisation: | 0.0 Mℓ/day |
| Raw Sewage Pump Station: | T-series Gormann Rupp |
| Screens: | Hand-raked 50 mm bar course screen and 10 mm Rotamat-type Huber fine screen |
| Grit Chambers: | Two vortex de-gritting systems |
| Aeration Basin: | Activated sludge (3-stage Phoredox) |
| Aeration Basin Capacity: | 2830 m ³ |
| Aerators: | Three slow speed mechanical aerators (30 kW each) |
| Clarifier Type: | Suction Lift Clarifier |
| Number of Clarifiers: | 2 |
| Total Area of all Clarifiers: | 158 m ² |
| Total Capacity of Clarifiers: | 2.28 Mℓ/day |
| Upflow Velocity: | 0.53 m/h |
| RAS Pump Station: | T-series Gormann Rupp |
| Chlorine Storage Capacity: | 2 x 1000 ℓ tanks |
| Chlorine Dosing Capacity: | 10 mg/ℓ Sodium Hypochlorite |
| Total Capacity of Chlorine Contact Tanks: | 70 m ³ |
| Sludge Treatment Process | Mechanical dewatering |
| Total Capacity of Sludge Treatment Plant: | Sludge Load Max 90 kgDS/hour, Hydraulic Load Max 4 m ³ /h |
| Sludge Drying Beds Area: | 1134 m ² (backup) |

b) Status Quo

Trust Feeds WWW has a design capacity of 1.0 Mℓ/day and is currently treating 0.00 Mℓ/day.



Figure 19.41 Location of Trust Feeds Wastewater Works.

c) Recommendations

The informal township of Trust Feeds lies adjacent to the Ridge Housing project and is currently serviced by VIPs. The area is considered peri-urban with potential to be converted to waterborne sanitation in future.

The main infrastructure elements to be upgraded/added include:

- A new main of 315 mm \varnothing will be required to cater for the flow generated from the township once converted.
- The Trust Feeds township is situated on a terrain that allows the future internal reticulation to gravitate towards the township's lowest point. At this lowest point the collected sewerage will need to be pumped across to the Trust Feeds WWW due to topological constraints. Therefore, a new pump station is proposed to cater for the flow generated from the township. The proposed pump station will have a pump duty flow of 37 ℓ/s .
- The pump station proposed in the section above will be accompanied by a proposed rising main leading to the Trust Feeds WWW. The proposed rising main will be approximately 1033 m in length and 200 mm \varnothing in size.

This project will be triggered when development of FDAs occurs. Conversion of peri-urban areas have been given a 30-year priority in the phasing approach employed. These works are therefore estimated to occur around 2051.

19.4 Recommended Projects

19.4.1 Darvill Wastewater Works Upgrade

| | |
|----------------|--------------|
| Planning No. | 104.1 |
| Project No. | UI0665A |
| Project Status | Construction |

(a) Project Description

The Darvill WWW serves the city of Pietermaritzburg and surrounding communities. All water borne sewage flows by gravity or is pumped to Darvill, with the exception of a small community in Lynnfield, which has its own water borne sewage that is treated by the Lynnfield Park WWW (**Section 19.3.3**). There are, however, large areas of the city that are not served by the sewer reticulation network that are reliant on on-site sanitation systems e.g. septic tanks and pit latrines. The extent of Darvill's water borne sewer catchment area is illustrated in **Figure 19.3**. Darvill WWW is thus of strategic importance to the city and to the environment at large as the quality of the effluent discharged needs to comply with regulations.

Demand was exceeding the treatment capacity of the works and a capacity upgrade was therefore required. It was also determined through process evaluations that the current process was inadequate and needed to be adapted.

The wastewater works is being upgraded from 65 Mℓ/day to 100 Mℓ/day to meet current and future demands (**Figure 19.42**). This is a comprehensive upgrade with the majority of the existing processes and infrastructure being impacted upon. Details of the process upgrades are given in **Table 19.14**.




Figure 19.42 Upgrade of Darvill WWWW.

Two key elements of the upgrade are the sludge treatment and biological treatment aeration system. The present method of disposal of sludge by spray irrigation to land is operating adequately, but has its limitations especially as the capacity of the works increases to address growth. A new method of sludge thickening and dewatering is to be implemented involving the construction of a new sludge treatment building. The new facility will use linear screens for mechanical thickening and dewatering of waste activated sludge and digester sludge.

The traditional surface aerators are inefficient, have been removed, and replaced by a fine bubble diffused aeration (FBDA) system. The FBDA system is made up of 22 680 diffusers in three aeration lanes that are connected by a pipe network that is supplied with air from four blowers. As opposed to surface aeration which requires a lot of mechanical energy to introduce oxygen into the system, FBDA release the air at the bottom of the aeration basin through the diffusers thus achieving an even dispersion and improved oxygen transfer.

Key information on this project is summarised in **Table 19.14**.

Table 19.14 Project information: Darvill Wastewater Works Upgrade.

| | |
|----------------------------|--|
| Project Components: | <ul style="list-style-type: none"> • Inlet Works <ul style="list-style-type: none"> ▪ New inlet works design to handle a maximum flow of 200 Mℓ/day in 4 channels. ▪ Two mechanical screens in each channel. • Fat, Oil, Grease (FOG) and Grit Removal <ul style="list-style-type: none"> ▪ Additional unit process because of high FOG loads in influent. ▪ 200 Mℓ/day in 3 lanes. • Primary Settling <ul style="list-style-type: none"> ▪ Additional 40 m PST added. • Settled Sewage Pump Station (SSPS) <ul style="list-style-type: none"> ▪ The SSPS replaces the existing “Main Pump Station” which has reached its design life. ▪ 3 duty, 1 standby and 1 spare. • Biological treatment <ul style="list-style-type: none"> ▪ Convert the existing anaerobic reactor to an activated sludge selector. ▪ Convert the existing Aerobic Reactor to an Anaerobic / Anoxic reactor. ▪ Construct a new deep basin reinforced concrete Aerobic Reactor with fine bubble diffused aeration (40 150 m³). • Air for Biological Treatment <ul style="list-style-type: none"> ▪ Blower House. ▪ 4 x 645 kW Blowers each with a rated delivery of 7 m³/sec @ 90 kPa. ▪ Air Header Mains. ▪ 22 680 diffusers in three aeration lanes. • Secondary Settling <ul style="list-style-type: none"> ▪ 2 x 35 m diameter secondary settling tanks. • Anaerobic Sludge Digesters <ul style="list-style-type: none"> ▪ 2 x 4500 m³ digesters. • Wash Water Treatment <ul style="list-style-type: none"> ▪ Construct 2 Mℓ/day wash water / reclamation plant. ▪ Unit processes will include disc filters, coagulation/flocculation, Ozonation granular activated carbon, ultra-filtration and hydrogen peroxide addition. |
| Capacity: | 100 Mℓ/day Plant |

(b) Institutional Arrangements

Umgeni Water owns and operates the plant and is funding the project internally. The Msunduzi Municipality is charged a monthly tariff for discharging the city's wastewater to Darvill.

(c) Beneficiaries

The Msunduzi Municipality is the main beneficiary of the upgrade as it will remove the constraint to development in the city.

(d) Implementation

Construction on this R977 million project (**Figure 19.43**) stopped when the lead contractor was placed in business rescue. The contract was subsequently terminated in April 2019. A new contractor was appointed in April 2020 to complete the outstanding works. The contractor established on site in September 2020 and it is now anticipated that the completion of the upgrade will be a year later than originally anticipated (March 2023). Some of the outstanding major works that required completion include the following:

- Digester complex
- Gravity belt thickeners

Completion certificates have been issued to the contractor for the following

- Lime dosing plant
- Sludge to lands pump station
- Inlet works
- Primary sedimentation tanks
- Biological treatment plant (the fourth Activated Sludge (AS) lane is now complete)
- Secondary reticulation
- Secondary settling tanks
- Tertiary treatment (the Chlorine plant and Scrubber and Wash Water / Reuse plant have been commissioned)



Figure 19.43 New head of works in the foreground with overflow channel teeing-off to the left.

19.4.2 Mpophomeni Wastewater Works Upgrade

| | |
|-----------------------|--------------------------|
| Planning No. | 610.1 |
| Project No. | UI0801A |
| Project Status | Detailed Design Complete |

(a) Project Description

The Mpophomeni WWT is currently not operational and sewage from Mpophomeni Township is pumped to the Howick WWT for treatment. The demand at Mpophomeni has increased to the extent that, on occasion, the flow exceeds the volume of effluent that the Howick WWT can treat. Additionally, there are a number of planned developments that will increase this flow significantly over the next few years. It was therefore proposed by UMDM that the Mpophomeni WWT be upgraded to treat 6 Mℓ/day with the possibility of upgrading the works to 12 Mℓ/day. The site has space for a plant of at least 20 Mℓ/day (**Figure 19.44**).

The following development initiatives by the municipality will be serviced by the Mpophomeni WWT, viz.:

- Refurbishment of the existing sewage reticulation system in Mpophomeni Township will increase wastewater flows to the works (ADWF 3.6 Mℓ/day);
- The development of the Khayelisha social housing development on the banks of Midmar Dam (ADWF 1.3 Mℓ/day); and
- Planned light/mixed industrial development park (3 Mℓ/day).

The effluent from the works will be pumped and disposed of to the Sakubula stream adjacent to the national road (N3) in Howick. The pumping main will be approximately 6.8 km in length and of various diameters.

Key information on this project is summarised in **Table 19.15**.

Table 19.15 Project information: Mpophomeni Wastewater Works Upgrade.

| | |
|----------------------------|--|
| Project Components: | <ul style="list-style-type: none"> • Inlet Works including a mechanical screen and vortex grit tanks (2No). • Two 14 m diameter primary settling tanks. • Primary sludge pump station. • Refurbished digesters with new heating and sludge circulating system. • Mechanical equipment to dewater digested primary and activated sludge. • 6 Mℓ/d (BNR Activated Sludge Treatment Plant). • Return Activated Sludge (RAS) pumping system. • Waste Activated Sludge (WAS) pumping system. • RAS and Storm Flow Recycle Refurbished Pump Station • Sludge and Storm Flow Recycle Mechanical/Electrical Plant. • Refurbished 2.25 Mℓ Storm bypass pond. • One 25 m diameter secondary clarifier. • One refurbished 18 m diameter secondary clarifier. • Aluminium sulphate, lime and chlorine chemical dosing systems. • Recycle pump station, pumping plant and pumping main from Maturation Ponds. • Disposal pipeline (6.8 km) of various diameters. • Pump station (2 duty, 1 stand-by) |
| Capacity: | 6 Mℓ/day Plant |




Figure 19.44 Upgrade of Mpophomeni WWWW.

(b) Institutional Arrangements

Umgeni Water will operate the plant on behalf UMDM under a twenty-year management contract. Umgeni Water is responsible for funding any capital improvements required by the plant. Umgeni Water charges a monthly management fee to the Municipality to cover all operation and maintenance costs and this fee includes capital redemption.

(c) Beneficiaries

UMDM and uMgeni Local Municipality are the main beneficiaries of the upgrade.

(d) Implementation

The construction is currently 70 % complete (**Figure 19.45**). The project is behind programme due to the COVID lockdown, civil unrest and local labour issues. The following points highlight the remaining major works:

- Completion of the main treatment processes and dismantling the existing HOW.
- Completion of the chlorine contact tank currently under construction.
- Completion of the maturation ponds.
- Completion of the pipeline from the WWW to Merrivale Outfall.

Contractually the due completion is scheduled for August 2022, however the planned completion is more likely to be December 2023.

The estimated cost of the project is R275 million at 2020 prices.



Figure 19.45: Mpophomeni Wastewater Works New Head of Works

19.4.3 Richmond Wastewater Works Upgrade

| | |
|----------------|-----------------|
| Planning No. | 610.3 |
| Project No. | UI0939A |
| Project Status | Detailed Design |

(a) Project Description

The Richmond WWW cannot currently cater for the peak demands placed on the infrastructure. As a result, UMDM have requested that Umgeni Water upgrade the Richmond WWW (**Figure 19.46**). The existing WWW serves the town of Richmond but not the low income settlements of Siyathuthuka and Lusaka that currently make use of pit latrines for basic sanitation. Once UMDM implements water borne sanitation in these low income areas then additional demand will be placed on the Richmond WWW. There are also some residential units located within the existing Richmond residential area that still need to be connected to the existing sewer network.

The proposed new extensions will cater for Biological Excess Phosphorous Removal with back-up chemical dosing facility. An increase in capacity of 1 Mℓ/day to 2 Mℓ/day is proposed.

Key information on this project is summarised in **Table 19.16**.

Table 19.16 Project information: Richmond Wastewater Works.

| | |
|----------------------------|---|
| Project Components: | <ul style="list-style-type: none"> • New inlet works including a mechanical screen, mechanical degritters, screenings conveyor and compactor and venture flume • 2 No additional aeration basins • Return Activated Sludge (RAS) pumping system • Waste Activated Sludge (WAS) pumping system • 1 No additional circular 18 m diameter secondary clarifier • New chlorine contact channel • Upgrade the existing chlorine dosing building and chlorine dosing equipment • New mechanical sludge handling equipment and housing building • New sludge drying beds and scum trap • New ferric dosing equipment • Refurbishment of sewage retention pond • Refurbishment of all ancillary facilities • New SCADA system |
| Capacity: | 5 Mℓ/day Plant |

(b) Institutional Arrangements

Umgeni Water will operate the plant on behalf of UMDM under a twenty-year management contract. Umgeni Water is responsible for funding any capital improvements required by the plant. Umgeni Water charges a monthly management fee to the Municipality to cover all operation and maintenance costs and capital redemption is included in this fee.

(c) Beneficiaries

UMDM and Richmond Local Municipality are the main beneficiaries of the upgrade.



Figure 19.46 Richmond WWW upgrade.

(d) Implementation

The estimated project cost is R127 million at 2020 prices. This figure includes the cost of all project phases: Planning, Design, Tender Preparation and Construction. Umgeni Water has shifted this project outside the five-year CAPEX window, which means that the project is on hold until further notice. This is in the main due to the current difficult economic conditions brought on by the Pandemic.

19.4.4 Mpofana Wastewater Works Upgrade

| | |
|----------------|---------|
| Planning No. | 610.2 |
| Project No. | UI0940A |
| Project Status | Tender |

(a) Project Description

Umgeni Water has a management contract with UMDM to operate and maintain the Mpofana WWW and two large sewage pump stations. The WWW services the town of Mooi River, which includes the adjacent township of Bruntville (**Figure 19.47**). The majority of the wastewater received by the works is domestic sewerage but there is also a large industrial component of between 1 to 2 Mℓ/day received from a textile factory situated adjacent to the works.

The works has a design capacity of 3.5 Mℓ/day and a reported operating capacity of 5 Mℓ/day. The works was receiving average dry weather inflows (AADW) of 6 Mℓ/day and was therefore operating above capacity. The demand has, however, reduced due to the temporary closing of the textile factory because of fire damage. Operational issues, as a result of aging infrastructure, have been identified at the works and these are being addressed. Umgeni Water has identified the need for increasing the treatment capacity to meet the future demands of Mooi River.

A PSP was appointed in 2018 to undertake the detailed feasibility and detailed design for the upgrade of the wastewater works.

(b) Institutional Arrangements

Umgeni Water currently operates the plant on behalf of UMDM under a twenty-year management contract. Umgeni Water is responsible for funding any capital improvements required at the plant. Umgeni Water charges a monthly management fee to the Municipality to cover all operation and maintenance costs and capital redemption is included in this fee.

(c) Beneficiaries

UMDM and Mpofana Local Municipality are the main beneficiaries of the upgrade.

(d) Implementation

The detailed feasibility study, including the environmental impact assessment and associated environmental specialist studies, was completed in December 2020. Following an assessment of the estimated costs of the upgrade (R350 - R400 million) the Project Steering Committee collectively agreed to suspend the study. In these difficult economic times, it was considered more prudent for the existing works to be refurbished at far lower cost. The Mpofana WWW will thus be refurbished with upgraded process capacity that will ensure efficient treatment and compliance with the regulated effluent discharge standards.

The results of the feasibility study will not be lost and will be shelved for use at a later date if needed.




Figure 19.47 Mpopana WWW upgrade.

19.4.5 Mkhambathini Wastewater Works Upgrade

| | |
|----------------|-----------------|
| Planning No. | 610.6 |
| Project No. | |
| Project Status | Detailed Design |

(a) Project Description

Umgeni Water has a management contract with UMDM to operate and maintain the Camperdown WWW. The WWW has a small demand (0.2 Mℓ/day) as a limited number of households are connected to the sewer reticulation network (**Figure 19.48**). The majority of households and businesses in the town still make use of on-site sanitation, such as septic tanks.

A feasibility study was undertaken which identified the need for a new WWW that would service all existing households and businesses as well as cater for future developments. A site west of the N3 freeway was identified (**Figure 19.48**) and detailed designs for a WWW and new bulk sewer network were completed.

The proposed works will include the construction of a bulk sewer network inclusive of three pump stations, as well as a 2Mℓ capacity wastewater treatment plant that will service the local population.

The proposed infrastructure (**Figure 19.49**) associated with the treatment process will consist of the following:

- Head of Works with mechanical screening and degritting, and a flow meter.
- Aeration Tank.
- Settling Tank (clarifier) to settle out and return the activated sludge back to the aeration tank.
- Chlorine dosage with contact tank, or Ultraviolet (UV) Irradiation for disinfection.
- Sludge Drying Beds for dewatering of activated sludge.

(b) Institutional Arrangements

Umgeni Water currently operates the Camperdown WWW on behalf of UMDM under a twenty-year management contract. It was identified by the feasibility study that Camperdown requires a new WWW that can serve the entire population and future development. As the existing WWW has insufficient capacity to meet future growth Umgeni Water will fund the construction and implementation of a new WWW from its CAPEX budget. Umgeni Water will charge a monthly management fee to the Municipality to cover the CAPEX and operation and maintenance of the new WWW once commissioned.

(c) Beneficiaries

UMDM and Mkhambathini Local Municipality are the main beneficiaries of the upgrade.

(d) Implementation

The detailed design phase is complete, but work has been temporality suspended until such time as funding is available. The new WWW requires the construction of a new sewage network and sewage pump stations, and this is the responsibility of UMDM. The estimated cost for the construction of the

WWW is R99 million at 2020 prices. UMDM recently submitted a proposal to the Department of Trade and Industry (DTI) to fund the bulk sewer reticulation component of the project.




Figure 19.48 Location of the proposed Mkhambathini WWW in relation to the existing Camperdown WWW.




Figure 19.49 Proposed Mkhambathini WWTW layout.

19.4.6 Hilton Bulk Wastewater Scheme

| | |
|----------------|----------------------|
| Planning No. | 610.8 |
| Project No. | |
| Project Status | Detailed Feasibility |

(a) Project Description

The study area of Hilton consists primarily of “old Hilton” (existing built up village) and “new Hilton” (area between the N3 national road and Hilton College). The greater Hilton area also includes the adjacent locality of Cedara.

There is a huge potential for commercial and residential property development within this greater area, which is located at a strategic location within the KwaZulu-Natal Midlands. To allow for the development potential to be unlocked, more wastewater treatment capacity will have to be developed. Currently, the existing sanitation infrastructure is primarily septic tanks with a few independent wastewater treatment package plants (WWTPP) and the Cedara WWW.

A pre-feasibility study for sub-regional bulk wastewater for the greater Hilton area within the uMngeni Local Municipality (LM) was completed in March 2019. Various bulk wastewater options were identified as well as a new wastewater works adjacent to Hilton College (**Figure 19.50**). Approval has now been obtained to take this study to detailed feasibility.

This project will investigate the feasibility of providing water borne sanitation, as a solution to deal with the increased sewage generation

The detailed feasibility study (DFS) will include the following:

- Assessment of town planning and spatial development planning;
- Determination of sewage flows;
- Land and geotechnical survey;
- Layout and longitudinal profiles of sewer outfall pipelines;
- Positioning of Waste Water Treatment Works (WWTW);
- Preliminary process design of WWTW;
- Estimating of Capital Costs; and
- Environmental Impact Assessment.

As this project is in its infancy, it will still be a number of years before implementation is undertaken. In the interim, there is a pressing need for sanitation services and Umgeni Water is addressing this through the construction of a 2 Mℓ/day WWW, commonly referred to as the “N3 Corridor WWW”. The WWW will be constructed adjacent to the Hilton Life Hospital in land obtained from Mondi. The WWW will be modular in nature with an initial treatment capacity of 1 Mℓ/day, upgradable to 2 Mℓ/day. The WWW should address the immediate and medium term sanitation needs of the area allowing development to expand.

(b) Institutional Arrangements

Umgeni Water operates many WWW on behalf of UMDM under a twenty-year management contract. As this is only a feasibility study there are, as yet, no institutional arrangements regarding this project.

(c) Beneficiaries

UMDM and uMngeni Local Municipality are the main beneficiaries of the study.

(d) Implementation

Request for Proposals (RFP) were issued in November 2022 to ten service providers utilising Umgeni Water's Framework Contract. The closing date for the tender is 31 January 2023. The SCM process will follow its course and the contract should be awarded by June 2023. The anticipated length of the detailed feasibility study is 24 months from the start date.




Figure 19.50 Proposed Hilton WWWW.

19.5 New Areas

New areas can be defined as those KZN WSAs for whom Umgeni Water is not the Bulk Water Service Provider (**Figure 1.1**) i.e. areas in KZN outside the Umgeni Water traditional area of supply. In some of these areas, Umgeni Water has received a mandate from the District Municipality to provide bulk water services, King Cetshwayo District Municipality being one of those. Umgeni Water's services are, at this stage, limited to potable water provision and no bulk wastewater infrastructure is presently being managed. The organisation's knowledge of the status of the bulk sanitation infrastructure throughout the province is thus limited to existing reports. Umgeni Water is committed to providing bulk water and sanitation throughout the province and therefore is in the process of obtaining as much sanitation information as possible from existing sources. With time, this information will have to be verified by site visits and possibly process audits so that the necessary infrastructure planning can take place. In the interim, however, the focus will be on identifying all the wastewater works within KZN and providing the salient infrastructure details.

The class of wastewater works is defined as A, B, C, D or E according to a scoring system derived from draft regulations published by the Department of Water and Sanitation. In general, the greater the capacity and the more sophisticated the treatment process the higher the class. A large WWW with a complex treatment process may be classified as Class A. Smaller more rudimentary WWW, only using saturation ponds, will be classified as Class E, such as Winterton (DWS, 2013).

19.5.1 uThukela District Municipality

a) Overview of the WWWs in uThukela District Municipality

The uThukela District Municipality (DM) has nine wastewater works, eight of which are operational (**Figure 19.51**). The capacity of the WWW ranges from very small (0.1 Mℓ/day) serving the small town of Winterton to relatively large (12 Mℓ/day) serving the large towns of Ladysmith, Estcourt and Ezakeni. A list of the WWW in the uThukela DM is provided in **Table 19.17** and a summary of each is provided in the sections hereafter

A number of sanitation projects have been implemented, are under construction or are proposed in the Municipality. A list of the sanitation projects funded by the Municipal Infrastructure Grant (MIG) and their status are provided in the **Table 19.18**.




Figure 19.51 Location of uThukela DM Wastewater Works

Table 19.17 uThukela District Municipality Wastewater Works Specifications (DWS, 2011)

| WWW | Description | Owner | Class | Capacity Sufficient | ADWF Capacity (Mℓ/day) | People Served | Operational | Overall Condition Rating (LTE, 2020) | Cost Estimate (LTE, 2020) |
|-----------|------------------|-------------|-------|---------------------|------------------------|---------------|-------------|--------------------------------------|---------------------------|
| Ezakeni | Activated Sludge | uThukela DM | C | Y | 12.0 | 38750 | Y | Poor | R 24 500 000 |
| Ekuvukeni | Activated Sludge | uThukela DM | D | Y | 2.4 | 8750 | N | Dysfunctional | R 33 000 000 |
| Bergville | Activated Sludge | uThukela DM | E | Y | 0.4 | 500 | Y | Fair | R 800 000 |
| Colenso | Activated Sludge | uThukela DM | E | Y | 3.2 | 6250 | Y | Poor | R 3 200 000 |
| Ladysmith | Bio-filter | uThukela DM | C | Y | 12.0 | 26250 | Y | Poor | R 27 500 000 |
| Estcourt | Activated Sludge | uThukela DM | D | Y | 12.0 | 10000 | N | Dysfunctional | R 16 200 000 |
| Weenen | Activated Sludge | uThukela DM | E | Y | 0.1 | 131 | N | Dysfunctional | R 15 000 000 |
| Winterton | Activated Sludge | uThukela DM | E | N | 1.25 | 188 | Y | Fair | R 5 600 000 |
| Wembezi | Activated Sludge | uThukela DM | E | N | 0.11 | 2500 | Y | Fair | R 2 500 000 |

Table 19.18 MIG funded Sanitation Projects in uThukela District Municipality (CoGTA KwaZulu-Natal,2020)

| Project | Status |
|---|------------------|
| Waterborne Sanitation Project Bergville Phase 2 | Construction 40% |
| Ezakheni Sanitation Project Phase 2 | Construction 80% |
| Weenen – Ezitendeni Sanitation Project | Construction 60% |
| Sanitation Coverage in Alfred Duma, Inkosi Langalibalele and Okhahlamba | Registered |
| UTDM COVID 19 Water & Sanitation Intervention Project | Registered |
| Winterton Sanitation Supply Scheme - Planning | Registered |

b) Estcourt Wastewater Works

The Estcourt WWTW services the town of Estcourt which is mostly on waterborne sanitation while surrounding townships are mostly serviced with VIPs. According to the Bigen Africa WSMP (2017) and the UTM Backlog Study, there are 2 910 households falling within the scheme footprint (**Figure 19.52**). Effluent flows predominantly to the Estcourt Sewer Pumping Station under gravity from where it is pumped via a bulk line to the WWTW.




Figure 19.52 Estcourt Wastewater Works Catchment Area

The Estcourt WWTW has two process streams that work in parallel (**Figure 19.53**). The streams are an aeration and biofiltration stream each to treat reticulated effluent as well as sludge from the surrounding townships employing on-site sanitation. Inflow to the works is a combination of residential, commercial and industrial wastewater. The influent has been noted as poor quality mainly due to the discharge from the Flamingo Moon Coffee Factory. At the works the biofiltration process is currently not operational due to many of the components requiring refurbishment, these include the primary settling tanks, the biofilters, humus tanks, anaerobic digesters, drying beds and internal pump stations. The aeration process stream handles the total inflow to the works. However, the intention for the future is for both streams to be working in conjunction to treat the inflow. At the head of the works conventional mechanical screening, grit removal and flow measurement is employed. Inflow to the works occurs at intervals as a result of automated control at the upstream pump station. Effluent is then treated in the mechanical aerator tank which has eight aerators of which five are operational, three require refurbishment. Further treatment is then intended at the two secondary clarifiers however both of which are not operational thereby reducing the effectiveness of the aeration process stream. As the last step in the process, the effluent passes through a maturation/polishing pond and the treated effluent is discharged via two Asbestos Cement pipes

(300mm and 450mm diameter) to the Bushman's River. Should the biofiltration stream receive the necessary refurbishment to full operational capacity then a portion of the effluent which passes through the inlet channel and screening will be treated at three primary settling clarifiers. In which process the sludge will be separated and pumped to two anaerobic digesters from which the solids will be sent to drying beds and the liquid component back to the head of the works to be re-cycled. After primary settlement, effluent will be pumped to an elevated biofilter tank after which it will pass through two stone filter tanks and humus tanks before being pumped back to the head of works to be recycled through the process. No contact tank for disinfection is provided and chlorination does not take place. Final treatment occurs at a single polishing pond before being discharged to the Bushman's River.




Figure 19.53 Estcourt Wastewater Process Flow Diagram

c) Wembezi Wastewater Works

The Wembezi WWW services portions of the township of Wembezi only (**Figure 19.54**). According to the Backlog Study referenced in the Bigen-Africa WSMP (2017), there are 299 households falling within the scheme footprint. Portions of Wembezi are serviced by a waterborne sewerage system whilst the remaining portions are assumed to currently be serviced by VIPs or septic tanks. Effluent flows to the Wembezi WWW under gravity as well as from one main pump station. The pump station is not operational, and the rising main is damaged resulting in raw sewage flowing into the Little Bushman’s River.




Figure 19.54 Wembezi Wastewater Works Catchment Area

The Wembezi WWTW receives residential influent only. The treatment process consists of three settling ponds (**Figure 19.55**). Influent passes through mechanical screening at the inlet from which it is distributed amongst three primary settling ponds. At the time of inspection, the manhole to one of the ponds was blocked and therefore the first pond was the only one receiving the flow. Thereafter the wastewater passes through all three maturation ponds in series before chlorination and ultimately discharge.




Figure 19.55 Wembezi Wastewater Works Process Flow Diagram

d) Weenen Wastewater Works

The Weenen sanitation scheme services the town of Weenen and the neighbouring township of KwaNobamba (**Figure 19.56**). According to the BA WSDP 2017 and its reference Backlog Study, there are 894 households falling within the scheme footprint. Weenen Town and KwaNobamba/Ezitenteni are currently serviced by septic tanks with the Weenen ponds receiving effluent from tankers only.




Figure 19.56 Weenen Wastewater Works Catchment Area

The WWTW consists of two concrete lined ponds and one plastic lined pond (**Figure 19.57**). The plastic lining is no longer in place. Indications are that the original design of the system was for a conventional process i.e., anaerobic digestion followed by aerobic treatment. However, due to underutilization, the treatment ponds are acting aerobically to treat the effluent.




Figure 19.57 Weenen Wastewater Works Process Flow Diagram

e) Ezakeni Wastewater Works

The Ezakheni sanitation scheme services the township of Ezakheni only (**Figure 19.58**). According to the BA WSMP 2017 and its referenced Backlog Study, there are 10 864 households falling within the scheme footprint. As per discussions with the Alfred Duma Superintendent, the Ezakheni WWW was built in the 1970s to treat domestic waste only. The development of the Ithala industrial area in the 1980s, has required process changes at the WWW to deal with the addition of industrial effluent. A sewer pump station with a 350mm diameter steel rising main pumps sewage to the Ezakheni WWW from the Ithala industrial area.

Ezakheni is serviced by a waterborne sewerage system. Effluent flows to the Ezakheni WWW under gravity as well as from nine sewage pumping stations all operated by the UTDM. Only sewerage from the Section B area gravitates to the Ezakheni WWW.

The WWW utilizes the combined process of activated sludge and bio filtration to treat effluent in a so-called Biological Nutrient Removal (BNR) process (**Figure 19.59**). It consists of holding tanks, screening, de-gritting channels, drying beds, two anaerobic ponds, humus tank, a backup generator, flow splitter, disinfection process and anaerobic digestion for sludge. There are six aerators, with only two in operation. There are three mixers, with only one in operation. There are two secondary settlement clarifiers and chlorine dosing tanks. The sludge pump house and control room consist of four pumps. The works received some refurbishment and upgrading by Talbot and Talbot in 2017 and is coping with the inflow. As per discussions with the superintendent, there is a huge shortage of houses in the Ezakheni area. New developments have been halted due to the shortfalls in the sewerage system.




Figure 19.58 Ezakheni Wastewater Works Catchment Area




Figure 19.59 Ezakheni Wastewater Works Process Flow Diagram

f) Ekuvukeni Wastewater Works

The Ekuvukeni sanitation scheme services the township of Ekuvukeni only (**Figure 19.60**). According to the BA WSMP 2017 and its referenced Backlog Study, there are 2 602 households falling within the scheme footprint. Ekuvukeni is serviced by a waterborne sewerage system. The WWTW receives effluent under gravity flow as well as from tankers. Only 30% of Ekuvukeni’s sewerage is connected (piped) to the WWTW.




Figure 19.60 Ekuvukeni Wastewater Works Catchment Area

The WWTW utilizes a combined process of extended aeration and activated sludge with biological nutrient removal to treat the sewerage influent (**Figure 19.61**). The works consists of screens, degritter channels, biological nutrient removal, a single clarifier/scrapper bridge, a return sludge pump, gas chlorination, maturation ponds, two mixers, axial flow rec pump, three aerators and waste sludge pump.




Figure 19.61 Ekuvukeni Wastewater Works Process Flow Diagram

g) Ladysmith Wastewater Works

The Ladysmith sanitation scheme services the town of Ladysmith and the neighbouring township of Steadville (**Figure 19.62**). According to the BA WSMP 2017 and its referenced Backlog Study, there were 9 522 households falling within the scheme footprint in 2017. Ladysmith and Steadville are serviced by a waterborne sewerage system. Effluent flows to the Ladysmith WWTW under gravity as well as from nineteen pump stations.




Figure 19.62 Ladysmith wastewater Works Catchment Area

The WWTW utilizes various treatment processes comprising of holding tanks, screening, de-gritting channels, flow measurement, flow splitting and disinfection. The bio filtration section of the plant is comprised of bio filters, humus tanks, anaerobic digesters, sludge digesters and maturation ponds (**Figure 19.63**).




Figure 19.63 Ladysmith Wastewater Works Process Flow Diagram

h) Colenso Wastewater Works

The Colenso sanitation scheme services the town of Colenso and the neighbouring township of Inkanyezi (**Figure 19.64**). According to the BA WSMP 2017 study and its referenced Backlog Study, there were 1 350 households falling within the scheme footprint in 2017. Colenso and Inkanyezi are serviced by a waterborne sewerage system. Effluent flows to the Colenso WWTW under gravity as well as from seven pump stations.




Figure 19.64 Colenso Wastewater Works Catchment Area

The WWTW process consists of an activated sludge system and utilizes combined screening, de-gritting, activated sludge, secondary settling, sludge drying and disinfection (**Figure 19.65**). Limited flow enters the works as a result of the various pump stations that are non-operational. The flow that does reach the works cannot be transferred to the next unit process when the screw pumps are not working. Two aerators and a RAS system are provided but occasional breakdown and overall mechanical malfunctioning reduces the plant's effectiveness.




Figure 19.65 Colenso Wastewater Works Process Flow Diagram

i) Bergville Wastewater Works

The Bergville sanitation scheme services the town of Bergville only. According to the Backlog Study, there are 228 households falling within the scheme footprint (Figure 19.66). Bergville is currently serviced by septic tanks with the Bergville WWT receiving effluent from tankers only. The works also accepts effluent from tankers from the nearby town of Winterton.




Figure 19.66 Bergville Wastewater Works Catchment Area

The existing WWW utilizes a series of oxidation ponds (**Figure 19.67**). Tankers discharge into a sump that flows through a screened inlet works to the ponds. The first two ponds are extremely silted up with limited process capacity. A floating aerator is located in the last pond but is non-operational. The effluent from the oxidation ponds is meant to flow to a system of four maturation ponds but these are also severely silted up and the effluent flows directly into the uThukela River. No provision for disinfection of the effluent is made.




Figure 19.67 Bergville Wastewater Works Process Flow Diagram

j) Winterton Wastewater Works

The Winterton scheme services the town of Winterton and the neighbouring township of Khethani. According to the Backlog Study, there are 146 households falling within the scheme footprint (Figure 19.68). Winterton and Khethani are mostly serviced by a waterborne sewerage system although some areas are believed to have septic tanks. Effluent flows to the Winterton WWTW under gravity as well as from one pump station.




Figure 19.68 Winterton Wastewater Works Catchment Area

The WWTW process consists of an inlet works and a poorly constructed flume. The effluent then enters an open septic tank before being pumped to a small stone biofilter. The biofilter underflow is then pumped to an aeration basin. Four drying beds are present but have not been utilized in a long time. A container-based chlorination system is provided (Figure 19.69).




Figure 19.69 Winterton Wastewater Works Process Flow Diagram

19.5.2 uMzinyathi District Municipality

The uMzinyathi District Municipality has nine WWW, seven of which are operational (**Figure 19.70**). The capacity of the WWWs range from very small (0.25 Mℓ/day) serving the community of Wasbank to small (3.2 Mℓ/day) serving the town of Greytown. A list of the WWW in the uMzinyathi DM is provided in **Table 19.19**.

A number of sanitation projects have been implemented, are under construction or are proposed in the Municipality. A list of the sanitation projects funded by the Municipal Infrastructure Grant (MIG) and their status are provided in **Table 19.20**.




Figure 19.70 Location of uMzinyathi Wastewater Works

Table 19.19 uMzinyathi District Municipality Wastewater Works Specifications (DWS, 2011)

| WWW | Description | Owner | Class | Capacity Sufficient | ADWF Capacity (Mℓ/day) | People Served | Operational | Overall Condition Rating (LTE, 2020) | Cost Estimate (LTE, 2020) |
|----------------|------------------|----------------|-------|---------------------|------------------------|---------------|-------------|--------------------------------------|---------------------------|
| Tugela Ferry | Activated Sludge | uThukela Water | D | N | 0.5 | 625 | Y | Fair | R 918 500 |
| Dundee-Glencoe | Activated Sludge | uThukela Water | B | Y | 10 | 12500 | Y | Fair | R 5 685 500 |
| Greytown | Activated Sludge | uThukela Water | D | N | 3.2 | 4000 | Y | Good | R 480 500 |
| Kranskop | None | uThukela Water | E | N | 0.0 | 63 | N | Fair | R 337 500 |
| Nondweni | Oxidation Ponds | uThukela Water | D | Y | 0.0 | 625 | N | Unknown | Unknown |
| Nqutu Hospital | Activated Sludge | uThukela Water | D | Y | 2.0 | 2500 | Y | Uunknown | Unknown |
| Nqutu Ponds | Oxidation Ponds | uThukela Water | E | Y | 3.0 | Unknown | Y | Fair | R 125 000 |
| Pomeroy | Oxidation Ponds | uThukela Water | D | Y | 1.0 | 1250 | Y | Fair | R1 003 000 |
| Wasbank | Activated Sludge | uThukela Water | D | Y | 0.25 | 625 | Y | Unknown | Unknown |

Table 19.20 MIG funded Sanitation Projects in uMzinyathi District Municipality (CoGTA KwaZulu-Natal)

| Project | Status |
|--|-----------------------|
| KwaSenge Sanitation Project | Design & Tender |
| Eradication of Sanitation Backlogs Umvoti LM | Construction 60% |
| Nquthu North Eastern Waterborne Sanitation Project | Feasibility Completed |
| Eradication of Msinga Sanitation Backlog | Construction 20% |
| Eradication of Nquthu Sanitation Backlogs | Construction 80% |

19.5.3 iLembe District Municipality

The iLembe District Municipality (DM) has 15 WWT including two that are operated by Siza Water (Frasers and Shakaskraal). All the wastewater works are reported operational with the exception of Melville, which has yet to be commissioned (**Figure 19.71**). The capacity of the WWT's range from very small (0.05 Mℓ/day) serving Ntunjambili Hospital to relatively large (12 Mℓ/day) serving the Sundumbili community. A list of the WWT in the iLembe DM is provided in **Table 19.21**.

19% of the population of iLembe DM still do not have access to basic sanitation. The urban areas have proper waterborne sanitation systems, but the peri-urban and rural areas rely on pit latrines or no system at all. Plans are currently in place to construct a regional wastewater scheme (in planning phase) in KwaDukuza to address the current infrastructure limitations of the area. Proposed wastewater works are planned for Ndwedwe, Mandeni, Maphumulo and various parts of KwaDukuza.

A number of sanitation projects have been implemented, are under construction or are proposed in the Municipality. A list of the sanitation projects funded by the Municipal Infrastructure grant (MIG) and their status are provided in **Table 19.22**.




Figure 19.71 Location of iLembe District Municipality Wastewater Works

Table 19.21 iLembe District Municipality Wastewater Works Specifications (DWS, 2011)

| WWW | Description | Owner | Class | Capacity Sufficient | ADWF Capacity (ME/day) | People Served | Operational | Overall Condition Rating (LTE, 2020) | Cost Estimate (LTE, 2020) |
|----------------------|------------------|------------|-------|---------------------|------------------------|---------------|-------------|--------------------------------------|---------------------------|
| Sundumbili | Bio-filter | iLembe DM | B | N | 12.0 | 15000 | Y | Poor | R 2 518 800 |
| Frasers | Activated Sludge | Siza Water | C | Y | 12.0 | 15000 | Y | Poor | R 441 000 |
| Mandeni | Activated Sludge | iLembe DM | D | Y | 1.3 | 1500 | Y | Poor | R 2 703 500 |
| Darnall | Activated Sludge | iLembe DM | D | Y | 0.33 | 375 | Y | Poor | R 1 728 200 |
| Shakaskraal | Activated Sludge | Siza Water | D | Y | 1.6 | 1500 | Y | Poor | R 440 000 |
| Stanger | Activated Sludge | iLembe DM | D | Y | 10.0 | 12500 | Y | Poor | R 2 297 500 |
| Tugela | Activated Sludge | iLembe DM | | Y | 0.75 | 750 | Y | Fair | R 660 500 |
| Maphumulo Hospital | Activated Sludge | iLembe DM | D | Y | 0.15 | 37 | Y | Fair | R 296 00 |
| Amatikulu | Activated Sludge | iLembe DM | D | Y | 0.25 | 250 | Y | Poor | R 757 000 |
| Gledhow | Activated Sludge | iLembe DM | C | Y | 3.0 | 250 | Y | Poor | R 3 148 000 |
| Melville | Not commissioned | iLembe DM | | Y | 0.06 | 0 | N | Fair | R 260 000 |
| Montebello Hospital | Activated Sludge | iLembe DM | D | Y | 0.15 | 188 | Y | Poor | R 2 540 000 |
| Ntunjambili Hospital | Activated Sludge | iLembe DM | D | Y | 0.05 | 375 | Y | Poor | R 1 922 000 |
| Sheffield | Activated Sludge | iLembe DM | | Y | 6.0 | Unknown | Y | Fair | R 97 000 |
| Vukile High School | Oxidation Ponds | iLembe DM | | Y | 0.03 | Unknown | Y | Fair | R 285 000 |

**Table 19.22 MIG funded Sanitation Projects in iLembe District Municipality (CoGTA
KwaZulu-Natal, 2021)**

| Project | Status |
|---|-------------------|
| Inyoni Housing Development Bulk Sewer Project | Construction 80% |
| Mandeni Sanitation Master Business Plan | Construction 80% |
| Ndwedwe Sanitation Master Business Plan | Construction 60% |
| Mdlebeni Sanitation Project | Construction 80% |
| Southern Regional Bulk Water and Sanitation Scheme | Construction 20% |
| Darnall Sewer Upgrade within Ward 2 of KwaDukuza Municipality | Design & Tender |
| Maphumulo Town WWW and Sewer Reticulation Phase 1 | Planning & Design |
| Groutville D Sanitation Project Phase 2 | Construction 40% |
| Driefontein Housing Sanitation Project – Planning Phase | Registered |
| Lindelani Upgrading of Sewer Reticulation Network | Construction 20% |
| KwaDukuza Regional Wastewater Works | Design & Tender |
| Mandafarm Waterborne Sanitation – Planning Phase (Mandeni Ward 7) | Registered |
| Construction of 10142 VIPs within Mandeni Municipality | Registered |
| Construction of 840 VIPs in Ndwedwe Ward 15 | Construction |
| Sundamuili Wastewater Works Addendum: Fees for Detailed Design | Registered |
| Frasers Wastewater Works Upgrade – Planning Phase | Registered |
| KwaDukuza Town Bulk Sewer Replacement and Upgrade | Registered |

19.5.4 Harry Gwala District Municipality

The Harry Gwala District Municipality (HGDM) has ten WWT, nine of which are operational (**Figure 19.72**). The capacity of the WWT's range from very small (0.1 Mℓ/day) serving the community of Franklin to small (1 Mℓ/day) serving the town of Ixopo. A list of the WWT in the Harry Gwala DM is provided in **Table 19.23**.

The municipality reported that sanitation backlogs have been eradicated in the Greater Kokstad Local Municipality. The municipality is working to eradicate sanitation backlogs in the remaining three local municipalities i.e. Dr Nkosazana Dlamini-Zuma, uMzimkhulu and uBuhlebezwe. The total sanitation backlog equates to 22 % of the households in HGDM without basic RDP sanitation.

A number of sanitation projects have been implemented, are under construction or are proposed in the HGDM. A list of the sanitation projects funded by the Municipal Infrastructure grant (MIG) and their status are provided in **Table 19.24**.




Figure 19.72 Location of Harry Gwala District Municipality Wastewater Works

Table 19.23 Harry Gwala District Municipality Wastewater Works Specifications (DWS, 2011)

| WWW | Description | Owner | Class: Harry Gwala | Capacity Sufficient | ADWF Capacity (Mℓ/day) | People Served | Operational | Overall Condition Rating (LTE, 2020) | Cost Estimate (LTE, 2020) |
|--------------------------------|------------------|-------------------|--------------------------|---------------------|---------------------------|---------------|-------------|---|---------------------------|
| Ixopo | Activated Sludge | Umgeni Water | C | Y | 0.95 | | Y | Good | - |
| Kokstad | Activated Sludge | Harry Gwala DM | C | Y | 6.4 | 22500 | Y | Poor | R 7 295 000 |
| Underberg | Package Plant | Harry Gwala DM | D | N | 0.1 | 125 | Y | Good | R 103 000 |
| Bulwer | Package Plant | Harry Gwala DM | C | Y | 0.08 | 125 | Y | Fair | R 2 079 000 |
| Franklin | Oxidation Ponds | Harry Gwala DM | D | Y | 0.1 | 125 | Y | Poor | R 2 765 000 |
| Hlanganani/Polela | Bio-filter | Harry Gwala DM | D | Y | 0.22 | 313 | N | Fair | R 304 000 |
| Riverside | Oxidation Ponds | Harry Gwala DM | E | Y | 0.36 | 500 | N | Dysfunctional | R 4 858 200 |
| St Apollinaris/Cento cow | Oxidation Ponds | Harry Gwala DM | D | Y | 0.09 | 125 | Y | Poor | R5 355 400 |
| Umzimkhulu | Oxidation Ponds | Harry Gwala DM | C | Y | 0.56 | 750 | Y | Fair | R 1 467 000 |
| Rietvlei | Package Plant | Harry Gwala DM | D | Y | Unknown | 625 | N | Dysfunctional | R 20 000 000 |

**Table 19.24 MIG funded Sanitation Projects in Harry Gwala District Municipality
(CoGTA KwaZulu-Natal, 2020)**

| Project | Status |
|---|----------------------|
| Umzimkhulu Urban and Peri Urban Sanitation | Construction 80% |
| Donnybrook Bulk Sewer Upgrade | Design & Tender |
| Upgrade of Fairview and Ixopo Sewer System | Design & Tender |
| Umzimkhulu Sewers Upgrade Phase 2 (Ward 16) | Design & Tender |
| Shayamoya Emergency Sewer Intervention | Construction 80% |
| Emergency Trunk Sewer Intervention Greater Kokstad | Practical Completion |
| Emergency Sewer Intervention for Bhongweni Area Greater Kokstad | Practical Completion |
| Himeville Sanitation Project | Registered |
| Ibisi Sewer Reticulation | Design & Tender |
| Universal Rural Sanitation Coverage Ubuhlebezwe | Construction 20% |
| Horseshoe Sanitation Project Phase 2 | Design & Tender |

19.5.5 Ugu District Municipality

The Ugu District Municipality (DM) has 16 WWWW, the majority of them small. All but one of them are reported as being operational (**Figure 19.73**). The capacity of the WWWWs range from very small (0.2 Mℓ/day) serving the community of Eden Wilds to relatively large (12 Mℓ/day) serving the large town of Port Shepstone. A list of the WWWW in the DM is provided in **Table 19.25**.

The urban areas within Ugu are located predominantly within a narrow coastal strip comprising erven occupied by a combination of permanent residents and local tourists who descend on the area during holiday periods. The Sanitation Services Master Plan (SSMP) (SSI, 2005) suggests that the water demand (and hence wastewater flows) in the peak December/January period is typically 33% higher than the annual average values. Although largely “residential” most urban areas include some “commercial” activity and there are some “light and/or service industrial” nodes particularly at Port Shepstone (Marburg) and at Park Rynie to a lesser extent. The urban sanitation comprises a combination of waterborne sewerage linked to wastewater works as well as a system of septic tanks and conservancy tanks in the less densely populated areas.

Most of the treatment facilities are owned and managed by Ugu although there are also a number of privately owned and managed, small sewage treatment plants,– mostly “package” plants. With the exception of Gamalakhe, the sewerage coverage of formal, urban areas, which have a municipal water connection, is approximately 30%.

A total estimated capital investment (2014) of the order of R 3 billion is required to reticulate and upgrade sanitation within the urban strip. The urban strip are areas adjoining the coastal and by nature of their density should be provided with reticulated, waterborne sewerage as opposed to a basic level of service viz. septic tanks.

A number of sanitation projects have been implemented, are under construction or are proposed in Ugu. A list of the sanitation projects funded by the Municipal Infrastructure grant (MIG) and their status are provided in **Table 19.26**.

Table 19.25 Ugu District Municipality Wastewater Works Specifications

| WWW | Description | Owner | Class | Capacity Sufficient | ADWF Capacity (Mℓ/day) | People Served | Operational | Overall Condition Rating (LTE, 2020) | Cost Estimate (LTE, 2020) |
|---------------------|------------------|--------|-------|---------------------|------------------------|---------------|-------------|--------------------------------------|---------------------------|
| Kwabonwa | Oxidation Ponds | Ugu DM | D | Y | 0.6 | 63 | Y | Fair | R 3 853 500 |
| Gamalakhe | Bio-filter | Ugu DM | C | Y | 3.0 | 2500 | Y | Fair | R 5 950 200 |
| Ramsgate | Activated Sludge | Ugu DM | C | N | 1.2 | 1125 | Y | Poor | R 2 542 700 |
| Uvongo | Activated Sludge | Ugu DM | B | Y | 2.4 | 1875 | Y | Fair | R 2 154 950 |
| Palm Beach | Activated Sludge | Ugu DM | C | Y | 0.7 | 750 | Y | Poor | R 2 850 000 |
| Umzinto | Activated Sludge | Ugu DM | C | Y | 2.5 | 2000 | Y | Fair | R 10 051 500 |
| Shelley Beach | Activated Sludge | Ugu DM | C | N | 0.75 | 875 | Y | Fair | R 8 059 500 |
| Scottburgh | Activated Sludge | Ugu DM | B | Y | 2.3 | 2250 | Y | Poor | R 9 627 500 |
| Margate | Activated Sludge | Ugu DM | B | Y | 0.6 | 6250 | Y | Fair | R 4 061 000 |
| Murchiston Hospital | Activated Sludge | Ugu DM | | Y | 0.2 | 2500 | Y | Fair | R 10 414 000 |
| Eden Wilds | Oxidation Ponds | Ugu DM | D | Y | 0.2 | 188 | Y | Fair | R 2 100 500 |
| Southbroom | Activated Sludge | Ugu DM | D | Y | 0.2 | 63 | N | Dysfunctional | R 5 301 500 |
| Harding | Activated Sludge | Ugu DM | C | Y | 1.6 | 563 | Y | Fair | R 1 232 000 |
| Hibberdene | Oxidation Ponds | Ugu DM | C | Y | 0.28 | | N | Decommissioned | |
| Mbango | Activated Sludge | Ugu DM | B | N | 12.0 | 11250 | Y | Poor | R 8 413 500 |
| Melville | Activated Sludge | Ugu DM | C | Y | 0.28 | 344 | Y | Fair | R 6 162 000 |
| Munster | Oxidation Ponds | Ugu DM | D | Y | 0.25 | 225 | Y | Poor | R 4 640 000 |

| | | | | | | | | | |
|-------------------|------------------|--------|---|---|------|-----|---|---------|-------------|
| Pennington | Oxidation Ponds | Ugu DM | C | N | 2.0 | 750 | Y | Fair | R 3 482 000 |
| Red Dessert | Activated Sludge | Ugu DM | D | Y | 0.6 | 563 | Y | Fair | R 1 842 500 |
| Skogheim-Bhobhoyi | Activated Sludge | Ugu DM | D | Y | 0.14 | 150 | Y | Unknown | R 482 000 |

Table 19.26 MIG funded Sanitation Projects in Ugu District Municipality (CoGTA KwaZulu-Natal, 2020)

| Project | Status |
|--|----------------------|
| Margate Sewer Pipeline Replacement | Construction 40% |
| Harding Sanitation Scheme Phase 3 | Construction 80% |
| Pennington Waterborne Bulk Sewer Sanitation Project | Construction 80% |
| Sanitation Refurbishment Phase 1 – Port Edward to Park Rynie | Construction 80% |
| Kwalatshoda Water and Sanitation Project | Construction 80% |
| Extension (5.5 MI/day)to uMbango WWW Planning Phase | Registered |
| New 1.5 MI/day Melville WWW Planning Phase | Registered |
| Masinenge/uVongo Sanitation Project | Construction |
| Umzinto WWW and Outfall Sewers Upgrade and Rehabilitation | Construction |
| Mkholombe Sanitation Project | Practical Completion |
| Hibiscus Coast Sanitation Project | Construction |
| Refurbishment of Scottburgh WWW – Phase 1 | Registered |
| Margate Extension 3 & 7 Sanitation Scheme – Ward 6 | Registered |

19.5.6 uMkhanyakude District Municipality

The uMkhanyakude District Municipality (UKDM) has 11 WWWs all of which are 1 Mℓ/day and smaller in capacity (**Figure 19.74**). A list of the WWW in the DM is provided in **Table 19.27**. The provision of appropriate sanitation in the DM is a serious issue with massive backlogs.

The percentage of households in the district with access to a flush toilet (connected to either a sewerage system or a septic tank) is only 13%, a figure significantly lower than the 45% at provincial level. About 18 % of households in UKDM do not have access to any form of sanitation facilities compared to only 6.3% at provincial level. The dominant forms of sanitation infrastructure in the district include ventilated improved pit latrines (25% of households) and unimproved pit toilets (19% of households).

The sanitation access backlogs were determined utilising a combination of Census 2011 and the Stats SA 2016 Community Survey. The sanitation backlog for the district was 43% in 2016 compared to 45% in 2011. This shows a very slow pace in the eradication of sanitation backlogs which can be attributed to the municipality's main focus on water provision. In accordance with the 2016 Community Survey, a total of 65 675 households have below minimum level of service in terms of sanitation access.

The sanitation eradication backlog cost is estimated at R 985 million assuming dry sanitation to all those households without access at present. Similar to the water backlogs eradication cost, this figure does not account for maintenance backlogs as there are some households which were previously served but their schemes are currently dysfunctional due to prolonged lack of maintenance.

A number of sanitation projects have been implemented, are under construction or are proposed in UKDM. A list of the sanitation projects funded by the Municipal Infrastructure Grant (MIG) and their status are provided in **Table 19.28**.




Figure 19.74 Location of uMkhanyakude District Municipality Wastewater Works

Table 19.27 uMkhanyakude District Municipality Wastewater Works Specifications (DWS, 2011)

| WWW | Description | Owner | Class | Capacity Sufficient | ADWF Capacity (Mℓ/day) | People Served | Operational | Overall Condition Rating (LTE, 2020) | Cost Estimate (LTE, 2020) |
|------------------|------------------|-----------------|---------|---------------------|------------------------|---------------|-------------|--------------------------------------|---------------------------|
| Jozini | Oxidation Ponds | uMkhanyakude DM | Unknown | N | 1.0 | 625 | Y | Fair | R 122 000 |
| Hluhluwe | Oxidation Ponds | uMkhanyakude DM | Unknown | Y | 0.75 | 250 | N | Dysfunctional | R 3738 000 |
| Mtubatuba | Activated Sludge | uMkhanyakude DM | E | Y | 0.7 | 2500 | Y | Poor | R 1 668 500 |
| Hlabisa Hospital | Activated Sludge | uMkhanyakude DM | E | Y | 0.75 | 625 | N | Dysfunctional | R 560 500 |
| St Lucia | Oxidation Ponds | uMkhanyakude DM | Unknown | Y | 1.0 | 1250 | Y | Fair | R 5 000 |
| Mseleni | Oxidation Ponds | uMkhanyakude DM | Unknown | Y | 0.7 | 625 | Y | Fair | R 1 000 000 |
| Bethesda | Activated Sludge | uMkhanyakude DM | Unknown | N | 1.0 | 375 | Y | Fair | R 1 657 000 |
| Ingwavuma | Oxidation Ponds | uMkhanyakude DM | Unknown | N | 1.0 | 625 | Y | Good | R 120 000 |
| KwaMsane | Activated Sludge | uMkhanyakude DM | Unknown | N | 1.0 | 1250 | Y | Poor | R 2 985 500 |
| Manguzi Hospital | Activated Sludge | uMkhanyakude DM | Unknown | N | 1.0 | 625 | Y | Poor | R 1 355 000 |
| Mkuze | Oxidation Ponds | uMkhanyakude DM | Unknown | N | 1.0 | 625 | Y | Fair | R 39 500 |

**Table 19.28 MIG funded Sanitation Projects in uMkhanyakude District Municipality
(CoGTA KwaZulu-Natal, 2020)**

| Project | Status |
|---|-------------------|
| Themba lethu Sanitation Project | Construction 40% |
| Jozini Low Cost Housing Sewer Upgrade | Construction 60% |
| Jozini Umhlabuyalingana VIP Sanitation Project | Registered (2018) |
| Refurbishment of Sewer Pipeline Umtuba LM | Registered (2019) |
| Upgrade of Hlabisa Town Sanitation System | Registered (2020) |
| Upgrade and Refurbishment of Manguzi WWW Collection Sewer and Outfall Phase 1 | Registered (2021) |

19.5.7 King Cetshwayo District Municipality

The King Cetshwayo District Municipality (KCDM) has 20 WWTW, the majority of them small, all of which are reported operational (**Figure 19.76**). The capacity of the WWTWs range from very small (0.08 Mℓ/day) serving the community of KwaBadda to relatively large (14.5 Mℓ/day) serving the town of Empangeni. A list of the WWTW in the DM is provided in **Table 19.29**.

The King Cetshwayo DM consists of largely rural areas where dry sanitation systems predominate due to the scattered nature of settlements. The exception is the City of uMhlathuze Municipality (CoU) that includes towns such as Empangeni and the industrial centre of Richards Bay. The bulk sanitation system in the CoU Municipality is managed by the City of uMhlathuze (CoU). The seven bulk sewerage sub-systems that together make up the CoU's existing (current) bulk sewerage system are listed in **Figure 19.75**.




Figure 19.75 City of uMhlathuze existing bulk sewerage sub-systems

It is important to note that, because of the City's proximity to the sea, some wastewater only receives primary treatment in the form of maceration and is then discharged directly to sea via sewer outfalls. Thus, a large proportion of the City's wastewater remains relatively untreated. It is estimated that the capacity of the Alton and Arboretum macerators is 7 and 12 Mℓ/day respectively.

Based on planned and approved developments, augmentation of the Alton and Arboretum systems is proposed by 7 and 5 Mℓ/day respectively. Present indications are that spare capacity exists at the Empangeni, eNseleni, eSikhaleni and Ngwelezane WWTW and no augmentation is currently required.

The City of uMhlathuze is considering closing the Vulindlela WWTW for operational reasons. In that event, sewage/wastewater could be transferred into the bulk.

A number of sanitation projects have been implemented, are under construction or are proposed in the CoU. A list of the sanitation projects funded by the Municipal Infrastructure grant (MIG) and their status are provided in **Table 19.30**.




Figure 19.76 Location of King Cetshwayo King Cetshwayo District Municipality Wastewater Works

Table 19.29 King Cetshwayo District Municipality Wastewater Works Specifications (DWS, 2011)

| WWW | Description | Owner | Class | Capacity Sufficient | ADWF Capacity (Mℓ/day) | People Served | Operational | Overall Condition Rating (LTE, 2020) | Cost Estimate (LTE, 2020) |
|--------------------------|-------------------------------|-------|-------|---------------------|------------------------|---------------|-------------|--------------------------------------|---------------------------|
| Vulindlela | Activated Sludge | CoU | D | Y | 3.0 | Unknown | Y | Fair | R 1 970 000 |
| Esikhawini | Activated Sludge | CoU | C | N | 12.5 | Unknown | Y | Fair | R 1 709 000 |
| Ekhombe | Unknown | KCDM | E | N | 0.15 | 1250 | Y | Poor | R 33 300 |
| Empangeni | Activated Sludge | CoU | B | Y | 14.5 | Unknown | Y | Fair | R 405 000 |
| Ngwelezane | Activated Sludge | CoU | C | Y | 5.8 | Unknown | Y | Fair | R 3 073 000 |
| Eshowe | Unknown | KCDM | E | N | 1.5 | 875 | Y | Fair | R 882 000 |
| King Dinizulu | Unknown | KCDM | D | Y | 0.7 | 1875 | Y | Poor | R 872 600 |
| Melmoth | Unknown | KCDM | E | Y | 0.4 | 500 | Y | Fair | R 450 000 |
| Mtunzini | Unknown | KCDM | E | Y | 0.32 | 375 | Y | Fair | R 340 000 |
| Nkandla | Unknown | KCDM | E | Y | 0.8 | 1050 | Y | Fair | R 169 000 |
| Nseleni | Activated Sludge | CoU | C | Y | 3.0 | Unknown | Y | Fair | R 938 100 |
| Catherine Booth Hospital | Unknown | KCDM | E | Y | 0.15 | 138 | Y | Poor | R 70 600 |
| Mbongolwane | Unknown | KCDM | E | Y | 0.2 | 270 | Y | Poor | R 1 227 000 |
| Gingindlovu | Unknown | KCDM | E | N | 0.8 | 1000 | Y | Poor | R 429 995 |
| Felixton | Transferred to Vulindlela WWW | CoU | | Y | 0.0 | | Y | Unknown | Transfer Pipeline |
| Ekuphumuleni Hospital | Unknown | KCDM | E | Y | 0.1 | 563 | Y | Poor | R 70 700 |
| Kwabadala | Unknown | KCDM | E | Y | 0.08 | 89 | Y | Dysfunctional | R 109 100 |

| | | | | | | | | | |
|----------------------------|---------|------|---|---|------|------|---|------|-------------|
| Ocean View | Unknown | KCDM | E | Y | 0.5 | 1050 | Y | Fair | R 915 500 |
| Owen Sithole Agric College | Unknown | KCDM | E | Y | 1.5 | 44 | Y | Poor | R 2 746 500 |
| St Mary's Hospital | Unknown | KCDM | E | Y | 0.45 | 0 | Y | Fair | R 210 000 |

Table 19.30 MIG funded Sanitation Projects in King Cetshwayo District Municipality (CoGTA KwaZulu-Natal, 2020)

| Project | Status |
|---|----------------------|
| Ntambanana Rural Sanitation Area Business Plan | Construction 60% |
| Nkandla VIP Sanitation Area Business Plan | Construction 80% |
| Umlalazi Sanitation Area Business Plan | Construction 80% |
| Upgrade of Sewer Infrastructure Melmoth | Completed |
| Upgrade of Sewer Infrastructure Eshowe | Practical Completion |
| Mthunzini Sanitation Project | Practical Completion |
| Upgrade of Sewer Infrastructure for Melmoth Phase 1 | Construction 20% |

19.5.8 Zululand District Municipality

The Zululand District Municipality (ZDM) has 19 WWWs (**Figure 19.77**), the majority of them being very small and rudimentary in nature (Class E). Fourteen of the wastewater works are reported as operational. The capacity of the WWW's range from very small (0.08 Mℓ/day) serving the Thlasizwe Hospital to relatively large (16 Mℓ/day) serving the town of Klipfontein. A list of the WWW in the ZDM is provided in **Table 19.31**.

In terms of sanitation, 34,973 or 19% of households have no access to sanitation. éDumbe carries the highest percentage with Nongoma (24%) and AbaQulusi and Ulundi at 22% respectively. Investment of R1.064 billion is required to eradicate the sanitation backlog.

Over the years the number of households and non-domestic customers with sanitation, in the district, has steadily increased – from 105 077, in the year 2011/12, to 117 228 in 2015/16. The number of ventilated pit-latrines has also steadily increased over the same period – from 69 475 to 84 105.

A number of sanitation projects have been implemented, are under construction or are proposed in the Municipality. A list of the sanitation projects funded by the Municipal Infrastructure Grant (MIG) and their status are provided in **Table 19.32**.




Figure 19.77 Location of Zululand District Municipality Wastewater Works

Table 19.31 Zululand District Municipality Wastewater Works Specifications (DWS, 2011)

| WWW | Description | Owner | Class | Capacity Sufficient | ADWF Capacity (Mℓ/day) | People Served | Operational | Overall Condition Rating (LTE, 2020) | Cost Estimate (LTE, 2020) |
|-----------------------|------------------|-------------|-------|---------------------|------------------------|---------------|-------------|--------------------------------------|---------------------------|
| Frishgewald | Oxidation Ponds | Zululand DM | | Y | 0.15 | 0 | Y | Unknown | R 425 000 |
| St Franics Hospital | Oxidation Ponds | Zululand DM | E | N | 0.12 | 250 | Y | Poor | R 4 027 500 |
| Ceza Hospital | Activated Sludge | Zululand DM | E | N | 0.2 | 250 | Y | Poor | R 1 028 000 |
| Nonggoma/Holiyoka | Oxidation Ponds | Zululand DM | C | Y | 3.0 | 3750 | N | Poor | R 1 029 000 |
| Thlasizwe Hospital | Oxidation Ponds | Zululand DM | E | Y | 0.08 | 103 | N | Poor | R 356 000 |
| Itshelejuba Hospital | Oxidation Ponds | Zululand DM | E | N | 0.18 | 225 | Y | Poor | R 1 056 000 |
| Pongola | Oxidation Ponds | Zululand DM | D | N | 2.0 | 2500 | Y | Fair | R 727 000 |
| James Nxumalo College | Oxidation Ponds | Zululand DM | E | N | 0.17 | 213 | Y | Fair | R1 119 000 |
| Nkojeni Hospital | Oxidation Ponds | Zululand DM | E | Y | 0.14 | 170 | Y | Unknown | R 190 000 |
| Ulundi | Activated Sludge | Zululand DM | C | Y | 5.0 | 6250 | Y | Poor | R 2 100 000 |
| Emondlo | Activated Sludge | Zululand DM | B | Y | 4.0 | 5000 | Y | Unknown | R 818 000 |
| Alfa Mine | Oxidation Ponds | Zululand DM | E | Y | 0.0 | 0 | N | Unknown | |
| Cliffdale-Vrede | Oxidation Ponds | Zululand DM | E | Y | 0.2 | 250 | N | Unknown | |
| Coronation | Oxidation Ponds | Zululand DM | D | N | 2.0 | 2500 | N | Dysfunctional | R 20 000 000 |
| Edumbe | Oxidation Ponds | Zululand DM | E | Y | 0.2 | 250 | Y | Fair | R 455 000 |
| Enyathi | Oxidation Ponds | Zululand DM | E | Y | 0.0 | 0 | N | Poor | R945 000 |

| | | | | | | | | | |
|-------------|------------------|-------------|---|---|------|-------|---|------|-------------|
| Hlobane | Activated Sludge | Zululand DM | C | Y | 6.0 | 7500 | Y | Poor | R 1 675 500 |
| Klipfontein | Activated Sludge | Zululand DM | B | Y | 16.0 | 20000 | Y | Poor | R 4 962 000 |
| Nkongolwane | Oxidation Ponds | Zululand DM | E | Y | 0.3 | 0 | Y | Poor | R 4 547 000 |

Table 19.32 MIG funded Sanitation Projects in Zululand District Municipality (CoGTA KwaZulu-Natal, 2020)

| Project | Status |
|-------------------------------------|---------------|
| Zululand Rural Sanitation: Phase 2D | Construct 80% |

19.5.9 Amajuba District Municipality

The Amajuba District Municipality (DM) has ten WWWW, nine of which are reported as being operational (**Figure 19.78**). The capacity of the WWWWs are generally 2 Mℓ/day and lower, however, the municipality is unique in that it has four wastewater exceeding 10 Mℓ/day in capacity with the largest servicing Newcastle at 25 Mℓ/day. A list of the WWWW in the DM is provided in **Table 19.33**.

About 58% (Community Survey 2016) of the households in Amajuba DM area have flush toilets that are connected to a sewerage system of some type. This is an improvement of 4% when compared to figures from Census 2011. The 2016 figures also indicate that only 41% of households in the ADM do not have any form of sanitation. There are, however, wide variations within the district.

- 74% of households in the eMadlangeni municipality do not have access to any form of toilet i.e. pit with no ventilation, other (home built or none)
- 7% of households within the Dannhauser municipality are below the basic level of service (backlog).
- Out of the three municipal areas, the highest level of service is found in Newcastle Municipality where over 68% of households have either flush or chemical toilets or pit latrines

A number of sanitation projects have been implemented, are under construction or are proposed in the Municipality. A list of the sanitation projects funded by the Municipal Infrastructure Grant (MIG) and their status are provided in **Table 19.34**.




Figure 19.78 Location of Amajuba District Municipality Wastewater Works

Table 19.33 Amajuba District Municipality Wastewater Works Specifications (DWS, 2011)

| WWW | Description | Owner | Class | Capacity Sufficient | ADWF Capacity (Mℓ/day) | People Served | Operational | Overall Condition Rating (LTE, 2020) | Cost Estimate (LTE, 2020) |
|----------------------------|------------------|----------------|-------|---------------------|------------------------|---------------|-------------|--------------------------------------|---------------------------|
| Utrecht | Oxidation Ponds | uThukela Water | D | Y | 1.0 | 1250 | N | Dysfunctional | R 2 595 000 |
| Charslestown Ponds | Oxidation Ponds | uThukela Water | E | Y | 0.5 | | Y | Poor | R 1 820 000 |
| Durnacol | Activated Sludge | uThukela Water | D | Y | 2.0 | 2500 | Y | Fair | R 2 480 000 |
| Tweediedale | Oxidation ponds | uThukela Water | D | Y | 2.0 | 2500 | Y | Poor | R 2 173 000 |
| Kilbarchin-Ngagane Village | Activated Sludge | uThukela Water | C | N | 0.5 | | Y | Fair | R 3 910 000 |
| Osizweni | Activated Sludge | uThukela Water | B | N | 15.0 | | N | Dysfunctional | R 7 522 000 |
| Madadeni | Activated Sludge | uThukela Water | B | N | 12.0 | | N | Dysfunctional | R 8 355 000 |
| Newcastle | Bio-filter | uThukela Water | B | Y | 25.0 | | N | Dysfunctional | R 9 915 000 |
| Welgedagd | Activated Sludge | uThukela Water | D | Y | 0.5 | 625 | N | Dysfunctional | R 1 692 000 |
| Madadeni Ponds | Oxidation ponds | uThukela Water | E | N | 12.0 | | Y | Poor | Unknown |

Table 19.34 MIG funded Sanitation Projects in Amajuba District Municipality (CoGTA KwaZulu-Natal, 2020)

| Project | Status |
|--|------------------|
| Emadlangeni Sanitation Project | Construction 80% |
| Goedehoop Bulk Water and Sanitation | Construction 20% |
| Dannhauser Housing Development Bulk Water and Sanitation | Construction 20% |
| Goedehoop Bulk Water and Sanitation Phase 2 | Registered |

REFERENCES

CoGTA KwaZulu-Natal, 2020. MIG Implementation Plan. Prepared by Project Management Unit CoGTA KZN Infrastructure. CoGTA KZN: Pietermaritzburg.

Department of Water Affairs, 2011. First order assessment of wastewater treatment plants in KwaZulu-Natal to determine critical refurbishment requirements.

Department of Water & Sanitation, 2013. Regulations relating to compulsory national standards for process controllers and water services works. Water Services Act, 1997. R.813.

LTE, 2020. Conduct assessment of the state of municipal water, sanitation and electricity infrastructure in the ten districts of KwaZulu-Natal. Prepared for CoGTA Province of KZN.

SMEC, 2022. uThukela District Municipality Sanitation Master Plan. Prepared for Umgeni Water

Umgeni Water. 2017. *Infrastructure Master Plan 2017 Volume 2 2017/2018 – 2047/2048 June 2017*. Pietermaritzburg: Umgeni Water.

Water & Wastewater Engineering, 2022. Umgungundlovu District Municipality Sanitation Master Plan. Prepared for Umgeni Water.

ACKNOWLEDGEMENTS

Umgeni Water's comprehensive 2022 Infrastructure Master Plan has been updated and improved to produce this 2023 version. The concerted effort of the Planning Services Department as a whole in producing this document is acknowledged and appreciated. This was all achieved under ever trying conditions with many staff working remotely whilst contending with the COVID-19 Lockdowns. Specific contributions by the various team members deserves acknowledgement:

- Alka Ramnath (Planner) Project management, Section 2, Spatial information, Research and input to all volumes
- Graham Metcalf (Geohydrologist) Groundwater and Wastewater
- Gavin Subramanian (Planning Engineer) Infrastructure on the North Coast System
- Angus Nicoll (Planning Engineer) Infrastructure on the South Coast and Mgeni Central Systems
- Vernon Perumal (Planning Engineer) Infrastructure on the uMkhomazi, Upper uMzintlava, Upper uMzimkhulu and the uMhlathuze and Middle uThukela Systems and compiling the Energy Section
- Mark Scott (Planning Engineer) Infrastructure on the Mgeni Inland, uMfolozi, uMkhuze, uPhongolo and Lake Sibiya Systems
- Nathaniel Padayachee (Planning Engineer) Infrastructure on the Upper uThukela and Buffalo Systems
- Ntuthuko Ngcamu (Head – Water Demand Management Unit) with support from Siphokazi Mabaso, Mathews Nokhanga and Dillon Jacks Water Demand Management Section
- Sakhile Hlalukane (Hydrologist) Water resources of the North Coast, South Coast and Upper uThukela Systems
- Sandile Sithole (Hydrologist) Water resources of all systems excluding the North Coast, South Coast and Upper uThukela Systems
- Mlungisi Shabalala (Hydrologist) Water resources of the Middle uThukela, uMhlathuze, uMfolozi, uMkhuze, uPhongolo and Lake Sibiya Systems
- Sithembile Mbonambi (Hydrologist – Graduate Trainee) Water resources of the uMkhomazi, Upper uMzintlava and Upper uMzimkhulu Systems

The 2023 Infrastructure Master Plan was not completed by the abovementioned people without the valued assistance of numerous other persons and parties. Their contributions are gratefully acknowledged. These include Umgeni Water and WSA Operations Staff, Umgeni Water's Water and Environment Department (water quality) and Umgeni Water's Process Services Department (process and treatment details for UW plants and others).

Kevin Meier,
MANAGER: PLANNING SERVICES